

# ASTA TYPE CERTIFICATE

## VERIFICATION OF TEST

**Project No:** G104238411 **Certificate No:** ASTA-TYPE-000133

**Applicant:** Veritek Engineering Pvt. Ltd.  
Plot No. 222, EL - Electronic Zone, T.T.C. Industrial Area, M.I.D.C., Mahape, New  
Mumbai - 400 701, India

**Apparatus:** 0.72/4kV (Um/ Insulation level), 50/60Hz, window type measuring current transformers:

- a) 100/5A, 5VA, Class 0.5, Class E insulation
- b) 200/5A, 10VA, Class 0.5, Class E insulation
- c) 300/5A, 10VA, Class 0.5, Class E insulation
- d) 400/5A, 5VA, Class 1, Class E insulation
- e) 600/5A, 10VA, Class 0.5, Class E insulation
- f) 1000/5A, 15VA, Class 0.5, Class E insulation
- g) 1600/5A, 15VA, Class 0.2S, Class E insulation
- h) 2500/5A, 15VA, Class 0.2S, Class E insulation
- i) 3000/5A, 15VA, Class 0.2S, Class E insulation
- j) 3000/5A, 45VA, Class 1 (Split core), Class H insulation
- k) 3000/5A, 15VA, Class 0.2S (ring type), Class E insulation

**Manufactured By:** Veritek Engineering Pvt. Ltd.  
Plot No. 222, EL - Electronic Zone, T.T.C. Industrial Area, M.I.D.C., Mahape, New  
Mumbai - 400 701, India

**Test Report No:** B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

**Designation:** VIPS

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

**IEC 61869-2: Edition 1.0: 2012-09 Clauses 7.2.2, 7.2.6, 7.2.201, 7.3.1, 7.3.4, 7.3.5, 7.3.6, 7.3.204 and 7.5.2 and the STL Guide to IEC 61869-2, Issue 1.1, 1<sup>st</sup> July 2016**

The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.



010

*C. Nick-Lewis*

Certification  
Engineer

*B. J. McGill*

Certification Officer

10 July 2020

Date

### Conditions of use:

ASTA Type Certificates, verification of test is issued by Intertek for the exclusive use of the party applying for the Certificate. Intertek assumes no liability to any parties other than those with which it has an agreement and then only in accordance with the agreed Terms and Conditions.

The Applicant is authorised to copy or distribute Certificates and Test Reports provided the entire contents are included, or Certificate Front Sheets accompanied by any associated pages on which are stated the assigned rated characteristics and no part is obscured or illegible. Permission must be obtained from Intertek before any other kind of reproduction is made.

The holder of a Certificate may claim in Trade Journals, Catalogues, Technical Articles etc., and without the prior approval of Intertek that the product identified in a Certificate is Certified.

To minimise the possibility of any misunderstanding such claims must clearly identify the product(s) certified or approved, the ratings verified and the Standard against which certification/approval has been made.

Any other use of the Intertek or ASTA brand must first be approved in writing by Intertek. Test results and ratings verified by testing included in the Certificate and related Test Reports shall relate specifically to the sample(s) tested.

### Authenticity:

Authenticity of any ASTA document can be confirmed by contacting the Intertek ASTA Certification Office at the following address:

Intertek Testing & Certification Ltd., Centre Court, Meridian Business Park, Leicester, LE19 1WD,  
United Kingdom. Email: [asta@intertek.com](mailto:asta@intertek.com)

**Project No:** G104238411 **Certificate No:** ASTA-TYPE-000133

Verification of: Current transformers

**Limitations of Use**

| Characteristic Verified  | Clause/<br>Subclause | Verified Tests and Ratings  |
|--|----------------------|---|
| <p><b>Temperature-rise test</b></p> <p>Rated continuous thermal current <math>I_{cth}</math></p> <ul style="list-style-type: none"> <li>a) 100/5A, 5VA, Class 0.5, Class E insulation</li> <li>b) 200/5A, 10VA, Class 0.5, Class E insulation</li> <li>c) 300/5A, 10VA, Class 0.5, Class E insulation</li> <li>d) 400/5A, 5VA, Class 1, Class E insulation</li> <li>e) 600/5A, 10VA, Class 0.5, Class E insulation</li> <li>f) 1000/5A, 15VA, Class 0.5, Class E insulation</li> <li>g) 1600/5A, 15VA, Class 0.2S, Class E insulation</li> <li>h) 2500/5A, 15VA, Class 0.2S, Class E insulation</li> <li>i) 3000/5A, 15VA, Class 0.2S, Class E insulation</li> <li>j) 3000/5A, 45VA, Class 1 (split core), Class H insulation</li> <li>k) 3000/5A, 15VA, Class 0.2S (ring type), Class E insulation</li> </ul> | <p><b>7.2.2</b></p>  | <p>-</p> <ul style="list-style-type: none"> <li>100/5A, 5VA</li> <li>200/5A, 10VA</li> <li>300/5A, 10VA</li> <li>400/5A, 5VA</li> <li>600/5A, 10VA</li> <li>1000/5A, 15VA</li> <li>1600/5A, 15VA</li> <li>2500/5A, 15VA</li> <li>3000/5A, 15VA</li> <li>3000/5A, 45VA</li> <li>3000/5A, 15VA</li> </ul> |
| <p><b>Tests for accuracy</b></p> <ul style="list-style-type: none"> <li>a) 100/5A, 5VA, Class 0.5, Class E insulation</li> <li>b) 200/5A, 10VA, Class 0.5, Class E insulation</li> <li>c) 300/5A, 10VA, Class 0.5, Class E insulation</li> <li>d) 400/5A, 5VA, Class 1, Class E insulation</li> <li>e) 600/5A, 10VA, Class 0.5, Class E insulation</li> <li>f) 1000/5A, 15VA, Class 0.5, Class E insulation</li> <li>g) 1600/5A, 15VA, Class 0.2S, Class E insulation</li> <li>h) 2500/5A, 15VA, Class 0.2S, Class E insulation</li> <li>i) 3000/5A, 15VA, Class 0.2S, Class E insulation</li> <li>j) 3000/5A, 45VA, Class 1 (split core), Class H insulation</li> <li>k) 3000/5A, 15VA, Class 0.2S (ring type), Class E insulation</li> </ul>   | <p><b>7.2.6</b></p>  | <p>-</p> <p>Verified</p>  |

**Project No:** G104238411 **Certificate No:** ASTA-TYPE-000133

**Limitations of Use**

| Characteristic Verified   | Clause/<br>Subclause | Verified Tests and Ratings                                |
|---|----------------------|---|
| <b>Short-time current tests</b>   | <b>7.2.201</b>       | Verified  |
| a) 100/5A, 5VA, Class 0.5<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:                |                      | $I_{th}$ : 6kA rms for 1 sec.<br>$I_{dyn}$ : 15kA peak    |
| b) 200/5A, 10VA, Class 0.5<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:               |                      | $I_{th}$ : 12kA rms for 1 sec.<br>$I_{dyn}$ : 30kA peak   |
| c) 300/5A, 10VA, Class 0.5<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:               |                      | $I_{th}$ : 18kA rms for 1 sec.<br>$I_{dyn}$ : 45kA peak   |
| d) 400/5A, 5VA, Class 1<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:                  |                      | $I_{th}$ : 24kA rms for 1 sec.<br>$I_{dyn}$ : 60kA peak   |
| e) 600/5A, 10VA, Class 0.5,<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:              |                      | $I_{th}$ : 36kA rms for 1 sec.<br>$I_{dyn}$ : 90kA peak   |
| f) 1000/5A, 15VA, Class 0.5<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:              |                      | $I_{th}$ : 60kA rms for 1 sec.<br>$I_{dyn}$ : 150kA peak  |
| g) 1600/5A, 15VA, Class 0.2S<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:             |                      | $I_{th}$ : 96kA rms for 1 sec.<br>$I_{dyn}$ : 240kA peak  |
| h) 2500/5A, 15VA, Class 0.2S<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:             |                      | $I_{th}$ : 150kA rms for 1 sec.<br>$I_{dyn}$ : 375kA peak |
| i) 3000/5A, 15VA, Class 0.2S<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:             |                      | $I_{th}$ : 60kA rms for 1 sec.<br>$I_{dyn}$ : 150kA peak  |
| j) 3000/5A, 45VA, Class 1 (split core)<br>Rated Short-time thermal Current:<br>Rated Dynamic Current:   |                      | $I_{th}$ : 60kA rms for 1 sec.<br>$I_{dyn}$ : 150kA peak  |
| k) 3000/5A, 15VA, Class 0.2S (ring type)<br>Rated Short-time thermal Current:<br>Rated Dynamic Current: |                      | $I_{th}$ : 60kA rms for 1 sec.<br>$I_{dyn}$ : 150kA peak  |

**Project No:** G104238411 **Certificate No:** ASTA-TYPE-000133

**Limitations of Use**

| Characteristic Verified   | Clause/<br>Subclause | Verified Tests and Ratings |
|---|----------------------|----------------------------|
| <b>Power-frequency voltage withstand tests on primary terminals</b>   | <b>7.3.1</b>         | Verified                   |
| a) 100/5A, 5VA, Class 0.5<br>b) 200/5A, 10VA, Class 0.5<br>c) 300/5A, 10VA, Class 0.5<br>d) 400/5A, 5VA, Class 1<br>e) 600/5A, 10VA, Class 0.5,<br>f) 1000/5A, 15VA, Class 0.5<br>g) 1600/5A, 15VA, Class 0.2S,<br>h) 2500/5A, 15VA, Class 0.2S<br>i) 3000/5A, 15VA, Class 0.2S<br>j) 3000/5A, 45VA, Class 1 (split core)<br>k) 3000/5A, 15VA, Class 0.2S (ring type) |                      | 4kV for 1minute            |
| <b>Power-frequency voltage withstand tests on secondary terminals</b>   | <b>7.3.4</b>         | Verified                   |
| a) 100/5A, 5VA, Class 0.5<br>b) 200/5A, 10VA, Class 0.5<br>c) 300/5A, 10VA, Class 0.5<br>d) 400/5A, 5VA, Class 1<br>e) 600/5A, 10VA, Class 0.5,<br>f) 1000/5A, 15VA, Class 0.5<br>g) 1600/5A, 15VA, Class 0.2S,<br>h) 2500/5A, 15VA, Class 0.2S<br>i) 3000/5A, 15VA, Class 0.2S<br>j) 3000/5A, 45VA, Class 1 (split core)<br>k) 3000/5A, 15VA, Class 0.2S (ring type) |                      | 4kV for 1minute            |
| <b>Verification of markings</b>   | <b>7.3.6</b>         | Verified                   |
| a) 100/5A, 5VA, Class 0.5<br>b) 200/5A, 10VA, Class 0.5<br>c) 300/5A, 10VA, Class 0.5<br>d) 400/5A, 5VA, Class 1<br>e) 600/5A, 10VA, Class 0.5,<br>f) 1000/5A, 15VA, Class 0.5<br>g) 1600/5A, 15VA, Class 0.2S,<br>h) 2500/5A, 15VA, Class 0.2S<br>i) 3000/5A, 15VA, Class 0.2S<br>j) 3000/5A, 45VA, Class 1 (split core)<br>k) 3000/5A, 15VA, Class 0.2S (ring type) |                      |                            |

**Project No:** G104238411 **Certificate No:** ASTA-TYPE-000133

**Limitations of Use**

| Characteristic Verified   | Clause/<br>Subclause  | Verified Tests and Ratings   |
|---|-----------------------|--|
| <p><b>Inter-turn overvoltage test</b></p> <p>a) 100/5A, 5VA, Class 0.5<br/>           b) 200/5A, 10VA, Class 0.5<br/>           c) 300/5A, 10VA, Class 0.5<br/>           d) 400/5A, 5VA, Class 1<br/>           e) 600/5A, 10VA, Class 0.5,<br/>           f) 1000/5A, 15VA, Class 0.5<br/>           g) 1600/5A, 15VA, Class 0.2S,<br/>           h) 2500/5A, 15VA, Class 0.2S<br/>           i) 3000/5A, 15VA, Class 0.2S<br/>           j) 3000/5A, 45VA, Class 1 (Split core)<br/>           k) 3000/5A, 15VA, Class 0.2S (ring type)</p>  | <p><b>7.3.204</b></p> | <p>Verified</p>  |
| <p><b>Determination of the instrument security factor (FS) of measuring current transformers</b></p> <p>a) 100/5A, 5VA, Class 0.5<br/>           b) 200/5A, 10VA, Class 0.5<br/>           c) 300/5A, 10VA, Class 0.5<br/>           d) 400/5A, 5VA, Class 1<br/>           e) 600/5A, 10VA, Class 0.5,<br/>           f) 1000/5A, 15VA, Class 0.5<br/>           g) 1600/5A, 15VA, Class 0.2S,<br/>           h) 2500/5A, 15VA, Class 0.2S<br/>           i) 3000/5A, 15VA, Class 0.2S<br/>           j) 3000/5A, 45VA, Class 1 (split core)<br/>           k) 3000/5A, 15VA, Class 0.2S (ring type)</p> | <p><b>7.5.2</b></p>   | <p>Verified</p> <p>FS = 5<br/>           FS = 5<br/>           FS = 5<br/>           FS = 5<br/>           FS = 5<br/>           FS = 5<br/>           FS = 5<br/>           FS = 5<br/>           FS = 5<br/>           FS = 5<br/>           FS = 10<br/>           FS = 5</p> |

**Project No:** G104238411    **Certificate No:** ASTA-TYPE-000133

## Certificate Contents:

The following documents are attached to and form part of this certificate:

| <b>Documents:</b>  | <b>Number of pages</b> |
|--|------------------------|
| Test Report no:<br>B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E | 48                     |
| Circuit diagrams   | 1                      |
| Oscillograms   | 11                     |
| Photographs  | 33                     |
| Drawings   | 11                     |

## Certificate Revision Amendment Table


| <b>Certificate Number</b> | <b>Issue Date</b> | <b>Amendment</b> |
|---------------------------|-------------------|------------------|
| ASTA-TYPE-000133          | 10 Jul 2020       | Initial issue    |
|                           |                   |                  |
|                           |                   |                  |

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

# ASTA

Page 1 of 48

- APPARATUS TESTED:** : 0.72/4kV (Um/ Insulation level), 50/60Hz, window type measuring current transformers:
- a) 100/5A, 5VA, Class 0.5, Class E insulation
  - b) 200/5A, 10VA, Class 0.5, Class E insulation
  - c) 300/5A, 10VA, Class 0.5, Class E insulation
  - d) 400/5A, 5VA, Class 1, Class E insulation
  - e) 600/5A, 10VA, Class 0.5, Class E insulation
  - f) 1000/5A, 15VA, Class 0.5, Class E insulation
  - g) 1600/5A, 15VA, Class 0.2S, Class E insulation
  - h) 2500/5A, 15VA, Class 0.2S, Class E insulation
  - i) 3000/5A, 15VA, Class 0.2S, Class E insulation
  - j) 3000/5A, 45VA, Class 1 (split core), Class H insulation
  - k) 3000/5A, 15VA, Class 0.2S (ring type), Class E insulation
- STANDARD:** : IEC 61869-2: Edition 1.0: 2012 – 09 and the STL Guide to IEC 61869-2, Issue 1.1, 1<sup>st</sup> July 2016
- MANUFACTURER:** : Veritek Engineering Pvt. Ltd.  
Plot No. 222, EL - Electronic Zone, T.T.C. Industrial Area,  
M.I.D.C., Mahape, New Mumbai - 400 701, India
- TESTING LABORATORY:** : TECNALIA Research & innovation  
Parque Científico y Tecnológico de Bizkaia  
Laida Bidea. Edificio 413, 48170 Zamudio, SPAIN
- APPROVED BY:** : Rajani Menon, ASTA Observer, Intertek
- 
- DATE:** : 25.06.2020



**CONTENTS**

**Record of proving tests:** Pages 1 to 48

**Diagram numbers:** B26-20-AA/D01

**Oscillogram:** B26-20-AA 004, 006, 008, 010, 013, 016, 018, 019, 020, 021, 023 and 027

**Photographs:** The following photographs are included in this document.

| Photograph No:             | Description.   |
|----------------------------|--|
| a) 100/5A, 5VA, Class 0.5  |  |
| B26-20-AA-01E/01           | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-01E/02           | Tests for accuracy   |
| B26-20-AA-01E/03           | Inter-turn overvoltage test  |
| B26-20-AA-01E/04           | Temperature-rise test  |
| B26-20-AA-01E/05           | Short-time current tests   |
| B26-20-AA-01E/06           | After short-time current tests   |
| b) 200/5A, 10VA, Class 0.5 |  |
| B26-20-AA-02E/01           | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-02E/02           | Tests for accuracy   |
| B26-20-AA-02E/03           | Inter-turn overvoltage test  |
| B26-20-AA-02E/04           | Temperature-rise test  |
| B26-20-AA-02E/05           | Short-time current tests   |
| B26-20-AA-02E/06           | After short-time current tests   |
| c) 300/5A, 10VA, Class 0.5 |  |
| B26-20-AA-03E/01           | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-03E/02           | Tests for accuracy   |
| B26-20-AA-03E/03           | Inter-turn overvoltage test  |
| B26-20-AA-03E/04           | Temperature-rise test  |
| B26-20-AA-03E/05           | Short-time current tests   |
| B26-20-AA-03E/06           | After short-time current tests   |
| d) 400/5A, 5VA, Class 1    |  |
| B26-20-AA-04E/01           | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-04E/02           | Tests for accuracy   |
| B26-20-AA-04E/03           | Inter-turn overvoltage test  |
| B26-20-AA-04E/04           | Temperature-rise test  |
| B26-20-AA-04E/05           | Short-time current tests   |
| B26-20-AA-04E/06           | After short-time current tests   |

**CONTENTS (contd.)**

| <b>Photograph No:</b>        | <b>Description.</b>  |
|------------------------------|--|
| e) 600/5A, 10VA, Class 0.5   |  |
| B26-20-AA-05E/01             | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-05E/02             | Tests for accuracy   |
| B26-20-AA-05E/03             | Inter-turn overvoltage test  |
| B26-20-AA-05E/04             | Temperature-rise test  |
| B26-20-AA-05E/05             | Short-time current tests   |
| B26-20-AA-05E/06             | After short-time current tests   |
| f) 1000/5A, 15VA, Class 0.5  |  |
| B26-20-AA-06E/01             | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-06E/02             | Tests for accuracy   |
| B26-20-AA-06E/03             | Inter-turn overvoltage test  |
| B26-20-AA-06E/04             | Temperature-rise test  |
| B26-20-AA-06E/05             | Short-time current tests   |
| B26-20-AA-06E/06             | After short-time current tests   |
| g) 1600/5A, 15VA, Class 0.2S |  |
| B26-20-AA-07E/01             | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-07E/02             | Tests for accuracy   |
| B26-20-AA-07E/03             | Inter-turn overvoltage test  |
| B26-20-AA-07E/04             | Temperature-rise test  |
| B26-20-AA-07E/05             | Short-time current tests   |
| B26-20-AA-07E/06             | After short-time current tests   |
| h) 2500/5A, 15VA, Class 0.2S |  |
| B26-20-AA-08E/01             | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-08E/02             | Tests for accuracy   |
| B26-20-AA-08E/03             | Inter-turn overvoltage test  |
| B26-20-AA-08E/04             | Temperature-rise test  |
| B26-20-AA-08E/05             | Short-time current tests   |
| B26-20-AA-08E/06             | After short-time current tests   |
| i) 3000/5A, 15VA, Class 0.2S |  |
| B26-20-AA-09E/01             | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-09E/02             | Tests for accuracy   |
| B26-20-AA-09E/03             | Inter-turn overvoltage test  |
| B26-20-AA-09E/04             | Temperature-rise test  |
| B26-20-AA-09E/05             | Short-time current tests   |
| B26-20-AA-09E/06             | After short-time current tests   |

**CONTENTS (contd.)**

| Photograph No:                           | Description.   |
|--|--|
| j) 3000/5A, 45VA, Class 1(split core)    |  |
| B26-20-AA-10E/01                         | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-10E/02                         | Tests for accuracy   |
| B26-20-AA-10E/03                         | Inter-turn overvoltage test  |
| B26-20-AA-10E/04                         | Temperature-rise test  |
| B26-20-AA-10E/05                         | Short-time current tests   |
| B26-20-AA-10E/06                         | After short-time current tests   |
| k) 3000/5A, 15VA, Class 0.2S (ring type) |  |
| B26-20-AA-11E/01                         | Power-frequency voltage withstand tests on primary and secondary terminals |
| B26-20-AA-11E/02                         | Tests for accuracy   |
| B26-20-AA-11E/03                         | Inter-turn overvoltage test  |
| B26-20-AA-11E/04                         | Temperature-rise test  |
| B26-20-AA-11E/05                         | Short-time current tests   |
| B26-20-AA-11E/06                         | After short-time current tests   |

**Schedule of drawings:** The following drawings are included in this document.

| Drawing number                    | Issue Status |            | Description                        |
|-----------------------------------|--------------|------------|------------------------------------|
|                                   | Revision     | Date       |                                    |
| VEPL / RA / VIPS 5010 - 100 / 5   | R - 0        | 07.12.2019 | Current Transformer VIPS 50102630  |
| VEPL / RA / VIPS 5010 - 200 / 5   | R - 0        | 07.12.2019 | Current Transformer VIPS 50102630  |
| VEPL / RA / VIPS 4010 - 300 / 5   | R - 0        | 07.12.2019 | Current Transformer VIPS 40103240  |
| VEPL / RA / VIPS 3010 - 400/5     | R - 0        | 07.12.2019 | Current Transformer VIPS 30103010  |
| VEPL / RA / VIPS 6310 - 600 / 5   | R - 0        | 07.12.2019 | Current Transformer VIPS 63104460  |
| VEPL / RA / VIPS 6310 - 1000 / 5  | R - 0        | 07.12.2019 | Current Transformer VIPS 63104460  |
| VEPL / RA / VIPS 8010 - 1600 / 5  | R - 0        | 07.12.2019 | Current Transformer VIPS 80105580  |
| VEPL / RA / VIPS 10030 - 2500 / 5 | R - 0        | 07.12.2019 | Current Transformer VIPS 100308510 |
| VEPL / RA / VIPS 10030 - 3000 / 5 | R - 0        | 07.12.2019 | Current Transformer VIPS 100308510 |
| VEPL / RA / VIPS SC04             | R - 0        | 20.03.2020 | SPLIT CORE CT VIPS SC04            |
| VEPL / RA / VIPS 11315940         | R - 0        | 20.03.2020 | RMCT BIG VIPS 11315940             |

The drawings were verified by the ASTA Observer as adequately representing the apparatus tested.

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

# ASTA

Page 5 of 48

### APPARATUS TESTED

- a) 100/5A, 0.72/4kV ( $U_m$ /Insulation level), 5VA, 0.5 class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |               |
|--|---------------|
| Manufacturer Name / Trademark:                 | Veritek       |
| Type:  | VIPS 50102630 |
| Rated Primary/Secondary Current:               | 100/5A        |
| Accuracy Class:                                | 0.5           |
| Rated Burden:                                  | 5VA           |
| Rated Frequency:                               | 50/60 Hz      |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 6kA rms       |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 15kA peak     |
| Purpose of Use:                                | Measuring     |
| Instrument Security Factor (FS):               | 5             |
| Application:                                   | Indoor        |
| Class of Insulation:                           | E             |

The manufacturer assigned a current ratio of 100/5A, rated short-time thermal current of 100A, rated short-time thermal current of 6kA rms for 1 second, and a rated dynamic current of 15kA peak, with the secondary winding short-circuited.

- b) 200/5A, 0.72/4kV ( $U_m$ /Insulation level), 10VA, 0.5 class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |               |
|--|---------------|
| Manufacturer Name / Trademark:                 | Veritek       |
| Type:  | VIPS 50102630 |
| Rated Primary/Secondary Current:               | 200/5A        |
| Accuracy Class:                                | 0.5           |
| Rated Burden:                                  | 10VA          |
| Rated Frequency:                               | 50/60 Hz      |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 12kA rms      |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 30kA peak     |
| Purpose of Use:                                | Measuring     |
| Instrument Security Factor (FS):               | 5             |
| Application:                                   | Indoor        |
| Class of Insulation:                           | E             |

The manufacturer assigned a current ratio of 200/5A, rated short-time thermal current of 200A, rated short-time thermal current of 12kA rms for 1 second, and a rated dynamic current of 30 kA peak, with the secondary winding short-circuited.

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

# ASTA

Page 6 of 48

### APPARATUS TESTED (continued)

- c) 300/5A, 0.72/4kV ( $U_m$ /Insulation level), 10VA, 0.5 class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |               |
|--|---------------|
| Manufacturer Name / Trademark:                 | Veritek       |
| Type:  | VIPS 40103240 |
| Rated Primary/Secondary Current:               | 300/5A        |
| Accuracy Class:                                | 0.5           |
| Rated Burden:                                  | 10VA          |
| Rated Frequency:                               | 50/60 Hz      |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 18kA rms      |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 45kA peak     |
| Purpose of Use:                                | Measuring     |
| Instrument Security Factor (FS):               | 5             |
| Application:                                   | Indoor        |
| Class of Insulation:                           | E             |

The manufacturer assigned a current ratio of 300/5A, rated short-time thermal current of 300A, rated short-time thermal current of 18kA rms for 1 second, and a rated dynamic current of 45kA peak, with the secondary winding short-circuited.

- d) 400/5A, 0.72/4kV ( $U_m$ /Insulation level), 5VA, 1 class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |               |
|--|---------------|
| Manufacturer Name / Trademark:                 | Veritek       |
| Type:  | VIPS 30103010 |
| Rated Primary/Secondary Current:               | 400/5A        |
| Accuracy Class:                                | 1             |
| Rated Burden:                                  | 5VA           |
| Rated Frequency:                               | 50/60 Hz      |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 24kA rms      |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 60kA peak     |
| Purpose of Use:                                | Measuring     |
| Instrument Security Factor (FS):               | 5             |
| Application:                                   | Indoor        |
| Class of Insulation:                           | E             |

The manufacturer assigned a current ratio of 400/5A, rated short-time thermal current of 400A, rated short-time thermal current of 24 kA rms for 1 second, and a rated dynamic current of 60 kA peak, with the secondary winding short-circuited.

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

# ASTA

Page 7 of 48

### APPARATUS TESTED (continued)

e) 600/5A, 0.72/4kV ( $U_m$ /Insulation level), 10VA, 0.5 class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |               |
|--|---------------|
| Manufacturer Name / Trademark:                 | Veritek       |
| Type:  | VIPS 63104460 |
| Rated Primary/Secondary Current:               | 600/5A        |
| Accuracy Class:                                | 0.5           |
| Rated Burden:                                  | 10VA          |
| Rated Frequency:                               | 50/60 Hz      |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 36kA rms      |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 90kA peak     |
| Purpose of Use:                                | Measuring     |
| Instrument Security Factor (FS):               | 5             |
| Application:                                   | Indoor        |
| Class of Insulation:                           | E             |

The manufacturer assigned a current ratio of 600/5A, rated short-time thermal current of 600A, rated short-time thermal current of 36 kA rms for 1 second, and a rated dynamic current of 90 kA peak, with the secondary winding short-circuited.

f) 1000/5A, 0.72/4kV ( $U_m$ /Insulation level), 15VA, 0.5 class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |               |
|--|---------------|
| Manufacturer Name / Trademark:                 | Veritek       |
| Type:  | VIPS 63104460 |
| Rated Primary/Secondary Current:               | 1000/5A       |
| Accuracy Class:                                | 0.5           |
| Rated Burden:                                  | 15VA          |
| Rated Frequency:                               | 50/60 Hz      |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 60kA rms      |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 150kA peak    |
| Purpose of Use:                                | Measuring     |
| Instrument Security Factor (FS):               | 5             |
| Application:                                   | Indoor        |
| Class of Insulation:                           | E             |

The manufacturer assigned a current ratio of 1000/5A, rated short-time thermal current of 1000A, rated short-time thermal current of 60 kA rms for 1 second, and a rated dynamic current of 150 kA peak, with the secondary winding short-circuited.

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

# ASTA

Page 8 of 48

### APPARATUS TESTED (continued)

- g) 1600/5A, 0.72/4kV ( $U_m$ /Insulation level), 15VA, 0.2S class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |               |
|--|---------------|
| Manufacturer Name / Trademark:                 | Veritek       |
| Type:  | VIPS 80105580 |
| Rated Primary/Secondary Current:               | 1600/5A       |
| Accuracy Class:                                | 0.2S          |
| Rated Burden:                                  | 15VA          |
| Rated Frequency:                               | 50/60 Hz      |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 96kA rms      |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 240 kA peak   |
| Purpose of Use:                                | Measuring     |
| Instrument Security Factor (FS):               | 5             |
| Application:                                   | Indoor        |
| Class of Insulation:                           | E             |

The manufacturer assigned a current ratio of 2500/5A, rated short-time thermal current of 2500A, rated short-time thermal current of 96 kA rms for 1 second, and a rated dynamic current of 240 kA peak, with the secondary winding short-circuited.

- h) 2500/5A, 0.72/4kV ( $U_m$ /Insulation level), 15VA, 0.2S class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |                |
|--|----------------|
| Manufacturer Name / Trademark:                 | Veritek        |
| Type:  | VIPS 100308510 |
| Rated Primary/Secondary Current:               | 2500/5A        |
| Accuracy Class:                                | 0.2S           |
| Rated Burden:                                  | 15VA           |
| Rated Frequency:                               | 50/60 Hz       |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 150kA rms      |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 375kA peak     |
| Purpose of Use:                                | Measuring      |
| Instrument Security Factor (FS):               | 5              |
| Application:                                   | Indoor         |
| Class of Insulation:                           | E              |

The manufacturer assigned a current ratio of 2500/5A, rated short-time thermal current of 2500A, rated short-time thermal current of 150 kA rms for 1 second, and a rated dynamic current of 375 kA peak, with the secondary winding short-circuited.

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

# ASTA

Page 9 of 48

### APPARATUS TESTED (continued)

- i) 3000/5A, 0.72/4kV ( $U_m$ /Insulation level), 15VA, 0.2S class, 50/60Hz, Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |                |
|--|----------------|
| Manufacturer Name / Trademark:                 | Veritek        |
| Type:  | VIPS 100308510 |
| Rated Primary/Secondary Current:               | 3000/5A        |
| Accuracy Class:                                | 0.2S           |
| Rated Burden:                                  | 15VA           |
| Rated Frequency:                               | 50/60 Hz       |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 60kA rms       |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 150kA peak     |
| Purpose of Use:                                | Measuring      |
| Instrument Security Factor (FS):               | 5              |
| Application:                                   | Indoor         |
| Class of Insulation:                           | E              |

The manufacturer assigned a current ratio of 3000/5A, rated short-time thermal current of 3000A, rated short-time thermal current of 60 kA rms for 1 second, and a rated dynamic current of 150 kA peak, with the secondary winding short-circuited.

- j) 3000/5A, 0.72/4kV ( $U_m$ /Insulation level), 45VA, 1 class, 50/60Hz, split core Window type Measuring Current Transformer.

The following values were assigned by the manufacturer:

|  |            |
|--|------------|
| Manufacturer Name / Trademark:                 | Veritek    |
| Type:  | VIPS SC04  |
| Rated Primary/Secondary Current:               | 3000/5A    |
| Accuracy Class:                                | 1          |
| Rated Burden:                                  | 45VA       |
| Rated Frequency:                               | 50/60 Hz   |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 60kA rms   |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 150kA peak |
| Purpose of Use:                                | Measuring  |
| Instrument Security Factor (FS):               | 10         |
| Application:                                   | Indoor     |
| Class of Insulation:                           | H          |

The manufacturer assigned a current ratio of 3000/5A, rated short-time thermal current of 3000A, rated short-time thermal current of 60 kA rms for 1 second, and a rated dynamic current of 150 kA peak, with the secondary winding short-circuited.



## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

# ASTA

Page 10 of 48

### APPARATUS TESTED (continued)

- k) 3000/5A, 0.72/4kV ( $U_m$ /Insulation level), 15VA, 0.2S class, 50/60Hz, window type (ring) measuring current transformer.

The following values were assigned by the manufacturer:

|  |               |
|--|---------------|
| Manufacturer Name / Trademark:                 | Veritek       |
| Type:  | VIPS 11315940 |
| Rated Primary/Secondary Current:               | 3000/5A       |
| Accuracy Class:                                | 0.2S          |
| Rated Burden:                                  | 15VA          |
| Rated Frequency:                               | 50/60 Hz      |
| Rated Short-time Thermal Current ( $I_{th}$ ): | 60kA rms      |
| Rated Dynamic Current ( $I_{dyn}$ ):           | 150kA peak    |
| Purpose of Use:                                | Measuring     |
| Instrument Security Factor (FS):               | 5             |
| Application:                                   | Indoor        |
| Class of Insulation:                           | E             |

The manufacturer assigned a current ratio of 3000/5A, rated short-time thermal current of 3000A, rated short-time thermal current of 60 kA rms for 1 second, and a rated dynamic current of 150 kA peak, with the secondary winding short-circuited.

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

# ASTA

Page 11 of 48

## CUSTOMER

Veritek Engineering Pvt. Ltd.  
Plot No. 222, EL - Electronic Zone,  
T.T.C. Industrial Area, M.I.D.C.,  
Mahape, New Mumbai - 400 701, India

## DATE OF RECEIPT OF APPARATUS

12<sup>th</sup> December 2019

## CUSTOMER ORDER NUMBER

997761-3

## MANUFACTURER

The manufacturer has declared that the apparatus was manufactured at the following location.

Veritek Engineering Pvt. Ltd.  
Plot No. 222, EL - Electronic Zone, T.T.C. Industrial Area, M.I.D.C.,  
Mahape, New Mumbai - 400 701, India

## WITNESSES OF THE TESTS:

1. Mrs. Rajani Menon, ASTA Observer, Intertek.
2. Mr. Iván Fernández Almaraz, Tecnia
3. Mr. Agustin Ramos, Tecnia
4. Mr. Luis Martinez, Tecnia
5. Mr. Sreekumar Peringoth, Intertek
6. Mr. Raakesh Verma, Veritek Engineering, India
7. Mr. Prakash Hirani, for Veritek Engineering, India

**LABORATORY**

*The apparatus was tested at:*

**Tecnalia Research and Innovation:**



TECNALIA Research & innovation  
Parque Científico y Tecnológico de Bizkaia  
Laida Bidea. Edificio 413

*The laboratory accreditation details are:*



This Laboratory is accredited by the Spanish National Accreditation Entity for Testing and Calibration Laboratories (ENAC) in accordance with ISO/IEC 17025, 2017. Certificate Number: LE/148. Further ENAC, SPAIN is a signatory to ILAC MRA based on its qualifying on APLAC MRA.



This Laboratory is recognised by Intertek ASTA against the requirements of BSEN ISO/IEC 17025: 2017 and the regulations of ASTA Recognised Laboratories by ASTA Intertek. Reference No. 2017-RTL-L2-243

**SCHEDULE OF TESTS**

Tests in accordance with IEC 61869-2: Edition 1.0: 2012-09 clauses 7.2.2, 7.2.6, 7.2.201, 7.3.1, 7.3.4, 7.3.5, 7.3.6, 7.3.204 and 7.5.2 and the STL Guide to IEC 61869-2, Issue 1.1, 1<sup>st</sup> July 2016

| Sr. No. | Test Details   | Clause no       | Page no |
|---------|--|-----------------|---------|
| 1       | Power-frequency voltage withstand tests on primary terminals                           | 7.3.1           | 14      |
| 2       | Power-frequency voltage withstand tests on secondary terminals                         | 7.3.4           | 14      |
| 3       | Tests for accuracy   | 7.3.5 and 7.2.6 | 14-16   |
| 4       | Verification of markings   | 7.3.6           | 16      |
| 5       | Inter-turn overvoltage test  | 7.3.204         | 17      |
| 6       | Determination of the instrument security factor (FS) of measuring current transformers | 7.5.2           | 18      |
| 7       | Temperature-rise test  | 7.2.2           | 19-25   |
| 8       | Short-time current tests   | 7.2.201         | 26-48   |

**1. Power-frequency voltage withstand tests on primary terminals (Clause 7.3.1)**

The test voltage was applied between the short-circuited primary winding and earth of each current transformer in succession. The current transformers withstood 4000V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding, connected together and earth. The secondary terminals and exposed metal parts were connected to earth during the test.

Observation: No unintentional disruptive discharge was observed during the test. The requirements of test were met as per the standard.

**2. Power-frequency voltage withstand tests on secondary terminals (Clause 7.3.4)**

The test voltage was applied between the short-circuited secondary winding and earth of each current transformer in succession. The current transformers withstood 4000V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary winding, connected together and earth. The primary terminals and exposed metal parts were connected to earth during the test.

Observation: No unintentional disruptive discharge was observed during the test. The requirements of test were met as per the standard.

Photograph nos.: B26-20-AA-01E/01, B26-20-AA-02E/01, B26-20-AA-02E/01, B26-20-AA-03E/01, B26-20-AA-04E/01, B26-20-AA-05E/01, B26-20-AA-06E/01, B26-20-AA-07E/01, B26-20-AA-08E/01, B26-20-AA-09E/01, B26-20-AA-10E/01 and B26-20-AA-11E/01

**3. Tests for accuracy (Clause 7.3.5)**

**Tests for ratio error and phase displacement of measuring current transformers (Clauses 7.2.6.201 and 7.3.5.201)**

The ratio error and phase displacement of the current transformers were measured at rated frequency and at 1% (for 0.2S class only), 5%, 20%, 100% and 120% of rated currents with 25% and 100% rated output.

| Rating: 100/5A<br>Class 0.5<br>5VA |       | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |      |      |      |
|------------------------------------|-------|-------------------------|---------|---------|---------|-------------------------------|------|------|------|
|                                    |       | at current (% of rated) |         |         |         | at current (% of rated)       |      |      |      |
|                                    |       | 5                       | 20      | 100     | 120     | 5                             | 20   | 100  | 120  |
| 25%VA                              | 1.5VA | -0.1094                 | -0.0958 | -0.0541 | -0.0499 | 11.67                         | 5.82 | 3.35 | 3.29 |
| 100%VA                             | 5VA   | -0.4170                 | -0.2420 | -0.1406 | -0.1451 | 9.73                          | 3.56 | 3.14 | 4.01 |

| Rating: 200/5A<br>Class 0.5<br>10VA |       | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |       |       |      |
|-------------------------------------|-------|-------------------------|---------|---------|---------|-------------------------------|-------|-------|------|
|                                     |       | at current (% of rated) |         |         |         | at current (% of rated)       |       |       |      |
|                                     |       | 5                       | 20      | 100     | 120     | 5                             | 20    | 100   | 120  |
| 25%VA                               | 2.5VA | 0.0914                  | 0.2290  | 0.2740  | 0.2770  | 19.53                         | 13.87 | 10.16 | 9.67 |
| 100%VA                              | 10VA  | -0.6850                 | -0.4060 | -0.1939 | -0.1662 | 17.57                         | 12.09 | 4.06  | 2.69 |

**3. Tests for accuracy (Clause 7.3.5) (Continued)**

Tests for ratio error and phase displacement of measuring current transformers (Clause 7.2.6.201 and 7.3.5.201) (Continued)

| Rating: 300/5A<br>Class 0.5<br>10VA |       | Ratio error ( $\pm\%$ ) |         |         |         | Phase displacement ( $\pm$ minutes) |       |      |       |
|-------------------------------------|-------|-------------------------|---------|---------|---------|-------------------------------------|-------|------|-------|
|                                     |       | at current (% of rated) |         |         |         | at current (% of rated)             |       |      |       |
|                                     |       | 5                       | 20      | 100     | 120     | 5                                   | 20    | 100  | 120   |
| 25%VA                               | 2.5VA | 0.1491                  | 0.2150  | 0.2320  | 0.2330  | 14.46                               | 11.20 | 8.99 | 8.51  |
| 100%VA                              | 10VA  | -0.4930                 | -0.3290 | -0.1722 | -0.1536 | 13.93                               | 10.81 | 2.80 | 1.418 |

| Rating: 400/5A<br>Class 1<br>5VA |       | Ratio error ( $\pm\%$ ) |        |        |        | Phase displacement ( $\pm$ minutes) |       |      |      |
|----------------------------------|-------|-------------------------|--------|--------|--------|-------------------------------------|-------|------|------|
|                                  |       | at current (% of rated) |        |        |        | at current (% of rated)             |       |      |      |
|                                  |       | 5                       | 20     | 100    | 120    | 5                                   | 20    | 100  | 120  |
| 25%VA                            | 1.5VA | 0.220                   | 0.320  | 0.364  | 0.373  | 18.28                               | 14.86 | 8.21 | 7.30 |
| 100%VA                           | 5VA   | -0.1507                 | 0.0207 | 0.1975 | 0.2100 | 17.78                               | 13.18 | 3.89 | 3.10 |

| Rating: 600/5A<br>Class 0.5<br>10VA |       | Ratio error ( $\pm\%$ ) |         |         |         | Phase displacement ( $\pm$ minutes) |       |      |      |
|-------------------------------------|-------|-------------------------|---------|---------|---------|-------------------------------------|-------|------|------|
|                                     |       | at current (% of rated) |         |         |         | at current (% of rated)             |       |      |      |
|                                     |       | 5                       | 20      | 100     | 120     | 5                                   | 20    | 100  | 120  |
| 25%VA                               | 2.5VA | 0.1407                  | 0.1756  | 0.1982  | 0.2060  | 15.94                               | 13.21 | 8.36 | 7.76 |
| 100%VA                              | 10VA  | -0.4510                 | -0.3300 | -0.0968 | -0.0687 | 18.23                               | 13.35 | 2.98 | 2.30 |

| Rating: 1000/5A<br>Class 0.5<br>15VA |        | Ratio error ( $\pm\%$ ) |         |         |         | Phase displacement ( $\pm$ minutes) |      |      |      |
|--------------------------------------|--------|-------------------------|---------|---------|---------|-------------------------------------|------|------|------|
|                                      |        | at current (% of rated) |         |         |         | at current (% of rated)             |      |      |      |
|                                      |        | 5                       | 20      | 100     | 120     | 5                                   | 20   | 100  | 120  |
| 25%VA                                | 3.75VA | -0.0272                 | 0.0517  | 0.0864  | 0.0942  | 13.30                               | 9.33 | 5.07 | 4.79 |
| 100%VA                               | 15VA   | -0.0434                 | -0.2620 | -0.1064 | -0.0957 | 4.9                                 | 7.61 | 2.23 | 2.21 |

| Rating: 1600/5A<br>Class 0.2S<br>15VA |        | Ratio error ( $\pm\%$ ) |         |         |         |         | Phase displacement ( $\pm$ minutes) |      |      |      |      |
|---------------------------------------|--------|-------------------------|---------|---------|---------|---------|-------------------------------------|------|------|------|------|
|                                       |        | at current (% of rated) |         |         |         |         | at current (% of rated)             |      |      |      |      |
|                                       |        | 1                       | 5       | 20      | 100     | 120     | 1                                   | 5    | 20   | 100  | 120  |
| 25%VA                                 | 3.75VA | -0.0896                 | 0.0016  | 0.0319  | 0.0165  | 0.0160  | 13.60                               | 9.51 | 6.82 | 5.47 | 5.85 |
| 100%VA                                | 15VA   | -0.3430                 | -0.1908 | -0.1201 | -0.0971 | -0.0843 | 13.19                               | 9.53 | 5.79 | 4.48 | 4.31 |

**3. Tests for accuracy (Clause 7.3.5) (Continued)**

Tests for ratio error and phase displacement of measuring current transformers (Clause 7.2.6.201 and 7.3.5.201) (Continued)

| Rating: 2500/5A<br>Class 0.2S<br>15VA |        | Ratio error (±%)        |        |        |        |        | Phase displacement (±minutes) |       |       |       |       |
|---------------------------------------|--------|-------------------------|--------|--------|--------|--------|-------------------------------|-------|-------|-------|-------|
|                                       |        | at current (% of rated) |        |        |        |        | at current (% of rated)       |       |       |       |       |
|                                       |        | 1                       | 5      | 20     | 100    | 120    | 1                             | 5     | 20    | 100   | 120   |
| 25%VA                                 | 3.75VA | -0.0044                 | 0.0765 | 0.0903 | 0.0951 | 0.1066 | 7.870                         | 3.500 | 2.600 | 2.130 | 1.968 |
| 100%VA                                | 15VA   | -0.0833                 | 0.0228 | 0.0474 | 0.0623 | 0.0639 | 6.580                         | 3.680 | 2.730 | 1.938 | 1.776 |

| Rating: 3000/5A<br>Class 0.2S<br>15VA |        | Ratio error (±%)        |         |         |         |         | Phase displacement (±minutes) |       |       |       |       |
|---------------------------------------|--------|-------------------------|---------|---------|---------|---------|-------------------------------|-------|-------|-------|-------|
|                                       |        | at current (% of rated) |         |         |         |         | at current (% of rated)       |       |       |       |       |
|                                       |        | 1                       | 5       | 20      | 100     | 120     | 1                             | 5     | 20    | 100   | 120   |
| 25%VA                                 | 3.75VA | -0.0716                 | -0.0059 | 0.0105  | 0.0173  | 0.0182  | 4.980                         | 2.580 | 1.880 | 1.422 | 1.348 |
| 100%VA                                | 15VA   | -0.1387                 | -0.0441 | -0.0213 | -0.0068 | -0.0043 | 5.180                         | 2.780 | 2.030 | 1.245 | 1.126 |

| Rating: 3000/5A<br>Class 0.2S<br>15VA<br>(Ring type) |        | Ratio error (±%)        |        |        |        |        | Phase displacement (±minutes) |       |       |       |       |
|--|--------|-------------------------|--------|--------|--------|--------|-------------------------------|-------|-------|-------|-------|
|  |        | at current (% of rated) |        |        |        |        | at current (% of rated)       |       |       |       |       |
|  |        | 1                       | 5      | 20     | 100    | 120    | 1                             | 5     | 20    | 100   | 120   |
| 25%VA  | 3.75VA | 0.0387                  | 0.0630 | 0.0685 | 0.0673 | 0.0658 | 4.510                         | 2.650 | 2.090 | 1.590 | 1.501 |
| 100%VA   | 15VA   | -0.0244                 | 0.0242 | 0.0369 | 0.0423 | 0.0400 | 4.910                         | 2.910 | 2.240 | 1.489 | 1.375 |

| Rating: 3000/5A<br>Class 1<br>45VA<br>(Split core) |         | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |       |       |       |
|--|---------|-------------------------|---------|---------|---------|-------------------------------|-------|-------|-------|
|  |         | at current (% of rated) |         |         |         | at current (% of rated)       |       |       |       |
|  |         | 5                       | 20      | 100     | 120     | 5                             | 20    | 100   | 120   |
| 25%VA  | 11.25VA | -0.0189                 | 0.0420  | 0.0745  | 0.0935  | 8.09                          | 7.68  | 7.11  | 5.16  |
| 100%VA   | 45VA    | -0.2410                 | -0.1598 | -0.0960 | -0.3110 | 14.94                         | 14.24 | 10.59 | 12.79 |

Observation: The turns ratio error and phase displacement at the rated frequency did not exceed the values given in clause 5.6.201.3 (Table 201 for classes 0.1 to 1 and Table 202 for Class 0.2S) of IEC 61869-2:2012.

Photograph nos.: B26-20-AA-01E/02, B26-20-AA-02E/02, B26-20-AA-02E/02, B26-20-AA-03E/02, B26-20-AA-04E/02, B26-20-AA-05E/02, B26-20-AA-06E/02, B26-20-AA-07E/02, B26-20-AA-08E/02, B26-20-AA-09E/02, B26-20-AA-10E/02 and B26-20-AA-11E/02

**4. Verification of markings (clause 7.3.6)**

The nameplate and terminal markings were verified for correctness and were satisfactory.

**RECORD OF PROVING TESTS**

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

**ASTA**

Page 17 of 48

**5. Inter-turn overvoltage test (Clause 7.3.204)**

The test was performed according to procedure B of clause no.7.3.204.

With the primary winding open-circuited, the test voltage was applied to the terminals of secondary winding for 15s of each current transformer.

Test frequency: 400Hz, Test duration: 15s

| Rating                 | Test voltage | Current* | Frequency | Result            |
|------------------------|--------------|----------|-----------|-------------------|
| 100/5A, 5VA, CI 0.5    | 150.33V      | 6.0511A  | 409.88 Hz | Withstood for 15s |
| 200/5A, 10VA, CI 0.5   | 279.167V     | 6.1138A  | 410.07Hz  | Withstood for 15s |
| 300/5A, 10VA, CI 0.5   | 220.833V     | 6.0442A  | 410.01Hz  | Withstood for 15s |
| 400/5A, 5VA, CI 1      | 183.333V     | 6.1605A  | 410.02Hz  | Withstood for 15s |
| 600/5A, 10VA, CI 0.5   | 258.333V     | 6.1304A  | 410.05Hz  | Withstood for 15s |
| 1000/5A, 15VA, CI 0.5  | 304.167V     | 6.1977A  | 409.99Hz  | Withstood for 15s |
| 1600/5A, 15VA, CI 0.2S | 400.000V     | 6.1905A  | 409.74Hz  | Withstood for 15s |
| 2500/5A, 15VA, CI 0.2S | 770.833V     | 6.0974A  | 409.08Hz  | Withstood for 15s |
| 3000/5A, 45VA, CI 1    | 1.00000kV    | 6.1628A  | 409.47Hz  | Withstood for 15s |
| 3000/5A, 15VA, CI 0.2S | 1.60417kV    | 6.6339A  | 409.04Hz  | Withstood for 15s |
| 3000/5A, 15VA, CI 0.2S | 1.06250kV    | 6.3476A  | 409.50Hz  | Withstood for 15s |

Note: \*The higher value of the secondary current was applied as required by the manufacturer

Result: The current transformers withstood the test voltage for 15s and there was no disruptive discharge and no damage in the insulation observed during and after the test.

Photograph nos.: B26-20-AA-01E/03, B26-20-AA-02E/03, B26-20-AA-02E/03, B26-20-AA-03E/03, B26-20-AA-04E/03, B26-20-AA-05E/03, B26-20-AA-06E/03, B26-20-AA-07E/03, B26-20-AA-08E/03, B26-20-AA-09E/03, B26-20-AA-10E/03 and B26-20-AA-11E/03



**6. Determination of the instrument security factor (FS) of measuring current transformers (Clause 7.5.2)**

With the primary winding open-circuited, the secondary winding of each transformer was energized at rated frequency by a substantially sinusoidal voltage. The voltage was increased until the exciting current  $I_e$  reached  $I_{sr} \times FS \times 10\%$ . The results obtained for each current transformer is reported below:

| Rating                 | FS | $I_e: I_{sr} \times FS \times 10\%$ | $I_e$ (Measured) | $E_{FS}$ (Measured) | $E_{FS}$ Limit |
|------------------------|----|-------------------------------------|------------------|---------------------|----------------|
| 100/5A, 5VA, CI 0.5    | 5  | 2.5A                                | 2.6807A          | 2.552V              | 6.119V         |
| 200/5A, 10VA, CI 0.5   | 5  | 2.5A                                | 2.6028A          | 2.662V              | 11.833V        |
| 300/5A, 10VA, CI 0.5   | 5  | 2.5A                                | 2.5519A          | 4.772V              | 11.822V        |
| 400/5A, 5VA, CI 1      | 5  | 2.5A                                | 2.5519A          | 3.372V              | 9.252V         |
| 600/5A, 10VA, CI 0.5   | 5  | 2.5A                                | 2.5510A          | 6.213V              | 13.667V        |
| 1000/5A, 15VA, CI 0.5  | 5  | 2.5A                                | 2.5396A          | 7.927V              | 20.307V        |
| 1600/5A, 15VA, CI 0.2S | 5  | 2.5A                                | 2.6582A          | 11.816V             | 24.952V        |
| 2500/5A, 15VA, CI 0.2S | 5  | 2.5A                                | 2.8230A          | 28.050V             | 31.175V        |
| 3000/5A, 45VA, CI 1    | 10 | 5A                                  | 5.0493A          | 59.992V             | 90.054V        |
| 3000/5A, 15VA, CI 0.2S | 5  | 2.5A                                | 2.5961A          | 34.408V             | 34.556V        |
| 3000/5A, 15VA, CI 0.2S | 5  | 2.5A                                | 2.6526A          | 32.944V             | 35.252V        |

The r.m.s. value of the terminal voltage was less than the secondary limiting e.m.f.  $E_{FS}$  calculated for each current transformer.

**7. Temperature-rise Tests (Clause: 7.2.2):**

The current transformers were mounted in a manner representative of the mounting in service and a continuous thermal current equal to the rated primary current at rated frequency was circulated in a primary conductor copper busbar passed through the window of the CTs. The sizes of the primary conductors were 1 x 30mm x 10 mm for the 100/5A, 200/5A, 300/5A and 400/5A CTs, 3 x 50mm x 6 mm for 600/5A and 1000/5A CTs, 1 x 50mm x 20mm for 1600/5A CT and 3 x 100mm x 10mm for 2500/5A and 3000/5A CTs. The rated burden was connected across the secondary winding terminals of the CTs.

K-Type thermocouples were used to measure the surface temperature of the CT's.

The ambient temperature was measured using thermocouples suspended in oil cups positioned around the CT at about half its height at a distance of about 1 metre from the CT's.

The CT's were tested in an environment substantially free from air currents.

The test current was applied until the temperature of the body of the CT reached a constant value (i.e. the variation did not exceed 1 K/h for 1 hour during three consecutive temperature-rise readings.).

The resistances of the secondary windings were measured immediately after shut down.

The temperature-rise measurements of the secondary terminals and body are listed in Table 1 and the values of the secondary winding and temperature-rises are listed in Table 2 for each current transformer.

The final winding temperature was determined by the formula:

$$\theta_t = \{R_t/R_0 [235 + \theta_0]\} - T$$

$R_t$  = Resistance at the instant of test switch off.

$R_0$  = Resistance at cold condition.

$T$  = 235 - Temperature constant for copper

$\theta_0$  = Temperature at cold winding resistance measurement

$$\Delta\theta = \theta_t - \theta_a$$

Where  $\theta_t$  = Final temperature of winding during temperature-rise test.

$\theta_a$  = Ambient temperature at the time of shut down

**7. Temperature-rise Tests (Clause: 7.2.2) (contd.)**

**a) Temperature-rise test results for 100/5A CT:**

**Table 1:**

| Thermo-couple No. | Measurement Point | Measured Temperature °C | Ambient Temperature °C | Temp. Rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 20.6                    | 16.5                   | 4.1                         | 75        |
| 102               | Body 2            | 20.4                    |                        | 3.9                         | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. Rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 0.0438                     | 0.0450            | 17.1                           | 23.8                         | 16.5                                  | 7.3                           | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-01E/04

**b) Temperature-rise test results for 200/5A CT:**

**Table 1:**

| Thermo-couple no. | Measurement point | Measured temperature °C | Ambient temperature °C | Temp. rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 26.7                    | 17.3                   | 9.4                         | 75        |
| 102               | Body 2            | 27.3                    |                        | 10.0                        | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 0.0846                     | 0.0898            | 18.0                           | 35.0                         | 17.3                                  | 17.7                          | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-02E/04

**7. Temperature-rise Tests (Clause: 7.2.2) (contd.)**

**c) Temperature-rise test results for 300/5A CT:**

**Table 1:**

| Thermo-couple No. | Measurement Point | Measured Temperature °C | Ambient Temperature °C | Temp. Rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 28.6                    | 18.2                   | 10.4                        | 75        |
| 102               | Body 2            | 27.8                    |                        | 9.6                         | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. Rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 0.0704                     | 0.0754            | 18.8                           | 37.6                         | 18.2                                  | 19.4                          | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-03E/04

**d) Temperature rise test results for 400/5A CT:**

**Table 1:**

| Thermo-couple no. | Measurement point | Measured temperature °C | Ambient temperature °C | Temp. rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 38.7                    | 19.2                   | 19.5                        | 75        |
| 102               | Body 2            | 39.9                    |                        | 20.7                        | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 0.1553                     | 0.1876            | 18.5                           | 72.1                         | 19.2                                  | 52.9                          | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-04E/04

**7. Temperature-rise Tests (Clause: 7.2.2) (contd.)**

**e) Temperature-rise test results for 600/5A CT:**

**Table 1:**

| Thermo-couple No. | Measurement Point | Measured Temperature °C | Ambient Temperature °C | Temp. Rise (Δt) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-------------------|-----------|
| 101               | Body 1            | 37.7                    | 17.9                   | 19.7              | 75        |
| 102               | Body 2            | 39.4                    |                        | 21.5              | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                     | Initial Temp. θ <sub>0</sub> in °C | Final Temp. θ <sub>t</sub> in °C | Ambient at shut down θ <sub>a</sub> in °C | Temp. Rise (Δt) (K) | Limit (K) |
|----------------------------|---------------------|------------------------------------|----------------------------------|---|---------------------|-----------|
| R <sub>0</sub> in Ω        | R <sub>t</sub> in Ω |                                    |                                  |   |                     |           |
| 0.1363                     | 0.1526              | 17.6                               | 50.0                             | 17.9                                      | 32.1                | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-05E/04

**f) Temperature rise test results for 1000/5A CT:**

**Table 1:**

| Thermo-couple no. | Measurement point | Measured temperature °C | Ambient temperature °C | Temp. rise (Δt) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-------------------|-----------|
| 101               | Body 1            | 53.9                    | 17.7                   | 36.2              | 75        |
| 102               | Body 2            | 54.2                    |                        | 36.5              | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                     | Initial Temp. θ <sub>0</sub> in °C | Final Temp. θ <sub>t</sub> in °C | Ambient at shut down θ <sub>a</sub> in °C | Temp. rise (Δt) (K) | Limit (K) |
|----------------------------|---------------------|------------------------------------|----------------------------------|---|---------------------|-----------|
| R <sub>0</sub> in Ω        | R <sub>t</sub> in Ω |                                    |                                  |   |                     |           |
| 0.2039                     | 0.2434              | 18.4                               | 69.8                             | 17.7                                      | 52.1                | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-06E/04

**7. Temperature-rise Tests (Clause: 7.2.2) (contd.)**

**g) Temperature-rise test results for 1600/5A CT:**

**Table 1:**

| Thermo-couple No. | Measurement Point | Measured Temperature °C | Ambient Temperature °C | Temp. Rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 47.1                    | 18.5                   | 65.6                        | 75        |
| 102               | Body 2            | 44.9                    |                        | 63.4                        | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. Rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 0.3151                     | 0.3984            | 18.0                           | 84.5                         | 18.5                                  | 66.0                          | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-07E/04

**h) Temperature-rise test results for 2500/5A CT:**

**Table 1:**

| Thermo-couple no. | Measurement point | Measured temperature °C | Ambient temperature °C | Temp. rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 47.5                    | 18.3                   | 29.2                        | 75        |
| 102               | Body 2            | 59.2                    |                        | 29.2                        | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 0.4287                     | 0.5432            | 17.7                           | 85.5                         | 18.3                                  | 67.2                          | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-08E/04

**7. Temperature-rise Tests (Clause: 7.2.2) (contd.)**

**i) Temperature-rise test results for 3000/5A, 15VA, 0.2S CT:**

**Table 1:**

| Thermo-couple No. | Measurement Point | Measured Temperature °C | Ambient Temperature °C | Temp. Rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 59.3                    | 20.2                   | 39.2                        | 75        |
| 102               | Body 2            | 44.9                    |                        | 24.8                        | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. Rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 0.4510                     | 0.5899            | 17.3                           | 95.0                         | 20.2                                  | 74.8                          | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-09E/04

**j) Temperature-rise test results for 3000/5A, 45VA, Class 1 CT (Split core):**

**Table 1:**

| Thermo-couple no. | Measurement point | Measured temperature °C | Ambient temperature °C | Temp. rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 117.0                   | 20                     | 97.0                        | 135       |
| 102               | Body 2            | 115.5                   |                        | 95.5                        | 135       |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 1.1034                     | 1.682             | 17.3                           | 149.6                        | 20.0                                  | 129.6                         | 135       |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-10E/04

**7. Temperature-rise Tests (Clause: 7.2.2) (contd.)**

k) Temperature-rise test results for 3000/5A, 15VA, Class 0.2S CT (ring type):

**Table 1:**

| Thermo-couple No. | Measurement Point | Measured Temperature °C | Ambient Temperature °C | Temp. Rise ( $\Delta t$ ) K | Limit (K) |
|-------------------|-------------------|-------------------------|------------------------|-----------------------------|-----------|
| 101               | Body 1            | 54.6                    | 20.0                   | 34.6                        | 75        |
| 102               | Body 2            | 51.5                    |                        | 31.5                        | 75        |

**Table 2:**

| Winding Resistance (S1 S2) |                   | Initial Temp. $\theta_0$ in °C | Final Temp. $\theta_t$ in °C | Ambient at shut down $\theta_a$ in °C | Temp. Rise ( $\Delta t$ ) (K) | Limit (K) |
|----------------------------|-------------------|--------------------------------|------------------------------|---------------------------------------|-------------------------------|-----------|
| $R_0$ in $\Omega$          | $R_t$ in $\Omega$ |                                |                              |                                       |                               |           |
| 0.4207                     | 0.5266            | 17.3                           | 78.1                         | 20.0                                  | 60.8                          | 75        |

**RESULT:** The temperature-rise of the secondary winding was within the limits specified by the standard.

Photograph no.: B26-20-AA-11E/04



## 8. Short-time Current Tests (Clause 7.2.201):

### Test conditions:

1. The test supply for the short-time current test: 50Hz with the supply neutral earthed and the short-circuit point not earthed.
2. The short-time current test was performed on the primary winding (by centralising the CT on a copper busbar) connected to source and the secondary winding terminals of the current transformer short circuited.
3. The following tests were conducted after the short-time current test:
  - a. Visual examination (Clause. No. 7.1.a)
  - b. Tests for ratio error and phase displacement of measuring current transformers (Clauses 7.2.6.201 and 7.3.5.201)
  - c. Power-frequency withstand tests on primary winding (at 90%)
  - d. Power-frequency withstand tests on secondary winding (at 90%)
  - e. Physical examination

**8. Short-time Current Tests (Clause 7.2.201) (continued):****a) Short-time current test for 100/5A CT:**

Test at rated short-time thermal current of 6kA rms for 1 sec and rated dynamic current of 15kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 20mm x 20mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 100/5A  |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 6kA rms   |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 15kA peak   |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-01E/05 and B26-20-AA-01E/06                         |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 15.80   | 6.059                         | 1.012                      | B26-20-AA004           |
| Date of test :10 <sup>th</sup> February 2020     |   |                               |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**a) Short-time current test for 100/5A CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 100/5A<br>Class 0.5<br>5VA |        |       | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |       |       |       |
|------------------------------------|--------|-------|-------------------------|---------|---------|---------|-------------------------------|-------|-------|-------|
|                                    |        |       | at current (% of rated) |         |         |         | at current (% of rated)       |       |       |       |
|                                    |        |       | 5                       | 20      | 100     | 120     | 5                             | 20    | 100   | 120   |
| Before test                        | 25%VA  | 1.5VA | -0.1094                 | -0.0958 | -0.0541 | -0.0499 | 11.67                         | 5.82  | 3.35  | 3.29  |
|                                    | 100%VA | 5VA   | -0.4170                 | -0.2420 | -0.1406 | -0.1451 | 9.73                          | 3.56  | 3.14  | 4.01  |
| After test                         | 25%VA  | 1.5VA | -0.0959                 | -0.0883 | -0.0493 | -0.0452 | 11.61                         | 5.92  | 3.46  | 3.39  |
|                                    | 100%VA | 5VA   | -0.4010                 | -0.2330 | -0.1337 | -0.1381 | 9.58                          | 3.53  | 3.04  | 3.93  |
| Difference                         | 25%VA  | 1.5VA | -0.0135                 | -0.0075 | -0.0048 | -0.0047 | 0.06                          | -0.10 | -0.11 | -0.10 |
|                                    | 100%VA | 5VA   | -0.0160                 | -0.0090 | -0.0069 | -0.0070 | 0.15                          | 0.03  | 0.10  | 0.08  |
| Limit                              |        |       | 0.75                    | 0.375   | 0.25    | 0.25    | 45                            | 22.5  | 15    | 15    |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination

**8. Short-time Current Tests (Clause 7.2.201) (continued):****b) Short-time current test for 200/5A CT:**

Test at rated short-time thermal current of 12kA rms for 1 sec and rated dynamic current of 30kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 20mm x 20mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 200/5A  |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 12kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 30kA peak   |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-02E/05 and B26-20-AA-02E/06                         |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 31.36   | 12.23                         | 1.003                      | B26-20-AA006           |
| Date of test : 10 <sup>th</sup> February 2020    |   |                               |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**b) Short-time current test for 200/5A CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 200/5A<br>Class 0.5<br>10VA |        |       | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |       |       |       |
|-------------------------------------|--------|-------|-------------------------|---------|---------|---------|-------------------------------|-------|-------|-------|
|                                     |        |       | at current (% of rated) |         |         |         | at current (% of rated)       |       |       |       |
|                                     |        |       | 5                       | 20      | 100     | 120     | 5                             | 20    | 100   | 120   |
| Before test                         | 25%VA  | 2.5VA | 0.0914                  | 0.2290  | 0.2740  | 0.2770  | 19.53                         | 13.87 | 10.16 | 9.67  |
|                                     | 100%VA | 10VA  | -0.6850                 | -0.4060 | -0.1939 | -0.1662 | 17.57                         | 12.09 | 4.06  | 2.69  |
| After test                          | 25%VA  | 2.5VA | 0.1015                  | 0.2340  | 0.2790  | 0.2800  | 19.12                         | 13.79 | 10.18 | 9.74  |
|                                     | 100%VA | 10VA  | -0.6700                 | -0.4040 | -0.1894 | -0.1620 | 17.43                         | 12.08 | 4.10  | 2.82  |
| Difference                          | 25%VA  | 2.5VA | -0.0101                 | -0.0050 | -0.0050 | -0.0030 | 0.41                          | 0.08  | -0.02 | -0.07 |
|                                     | 100%VA | 10VA  | -0.0150                 | -0.0020 | -0.0045 | -0.0042 | 0.14                          | 0.01  | -0.04 | -0.13 |
| Limit                               |        |       | 0.75                    | 0.375   | 0.25    | 0.25    | 45                            | 22.5  | 15    | 15    |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**c) Short-time current test for 300/5A CT:**

Test at rated short-time thermal current of 18kA rms for 1 sec and rated dynamic current of 45kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 20mm x 20mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 300/5A  |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 18kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 45kA peak   |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-03E/05 and B26-20-AA-03E/06                         |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 46.81   | 18.41                         | 1.002                      | B26-20-AA008           |
| Date of test : 10 <sup>th</sup> February 2020    |   |                               |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**c) Short-time current test for 300/5A CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 300/5A<br>Class 0.5<br>10VA |        |       | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |       |       |       |
|-------------------------------------|--------|-------|-------------------------|---------|---------|---------|-------------------------------|-------|-------|-------|
|                                     |        |       | at current (% of rated) |         |         |         | at current (% of rated)       |       |       |       |
|                                     |        |       | 5                       | 20      | 100     | 120     | 5                             | 20    | 100   | 120   |
| Before test                         | 25%VA  | 2.5VA | 0.1491                  | 0.2150  | 0.2320  | 0.2330  | 14.46                         | 11.20 | 8.99  | 8.51  |
|                                     | 100%VA | 10VA  | -0.4930                 | -0.3290 | -0.1722 | -0.1536 | 13.93                         | 10.81 | 2.80  | 1.418 |
| After test                          | 25%VA  | 2.5VA | 0.1583                  | 0.2220  | 0.2370  | 0.2330  | 14.58                         | 11.46 | 9.03  | 8.44  |
|                                     | 100%VA | 10VA  | -0.4910                 | -0.3260 | -0.1745 | -0.176  | 14.09                         | 11.01 | 2.94  | 1.768 |
| Difference                          | 25%VA  | 2.5VA | -0.0092                 | -0.0070 | -0.0050 | 0.0000  | -0.12                         | -0.26 | -0.04 | 0.07  |
|                                     | 100%VA | 10VA  | -0.0020                 | -0.0030 | 0.0023  | 0.0224  | -0.16                         | -0.20 | -0.14 | -0.35 |
| Limit                               |        |       | 0.75                    | 0.375   | 0.25    | 0.25    | 45                            | 22.5  | 15    | 15    |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):****d) Short-time current test for 400/5A CT:**

Test at rated short-time thermal current of 24kA rms for 1 sec and rated dynamic current of 60kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 20mm x 20mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 400/5A  |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 24kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 60kA peak   |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-04E/05 and B26-20-AA-04E/06                         |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 61.78   | 24.24                         | 1.012                      | B26-20-AA010           |
| Date of test : 10 <sup>th</sup> February 2020    |   |                               |                            |                        |



**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**d) Short-time current test for 400/5A CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 400/5A<br>Class 1<br>5VA |        |       | Ratio error (±%)        |         |        |        | Phase displacement (±minutes) |       |       |       |
|----------------------------------|--------|-------|-------------------------|---------|--------|--------|-------------------------------|-------|-------|-------|
|                                  |        |       | at current (% of rated) |         |        |        | at current (% of rated)       |       |       |       |
|                                  |        |       | 5                       | 20      | 100    | 120    | 5                             | 20    | 100   | 120   |
| Before test                      | 30%VA  | 1.5VA | 0.2200                  | 0.3200  | 0.3640 | 0.3730 | 18.28                         | 14.86 | 8.21  | 7.30  |
|                                  | 100%VA | 5VA   | -0.1507                 | 0.0207  | 0.1975 | 0.2100 | 17.78                         | 13.18 | 3.89  | 3.10  |
| After test                       | 30%VA  | 1.5VA | 0.2300                  | 0.3230  | 0.3570 | 0.3730 | 20.10                         | 15.37 | 8.34  | 7.37  |
|                                  | 100%VA | 5VA   | -0.1605                 | 0.0050  | 0.1765 | 0.2140 | 19.30                         | 14.19 | 4.88  | 3.29  |
| Difference                       | 30%VA  | 1.5VA | -0.0100                 | -0.0030 | 0.0070 | 0.0000 | -1.82                         | -0.51 | -0.13 | -0.07 |
|                                  | 100%VA | 5VA   | 0.0098                  | 0.0157  | 0.021  | -0.004 | -1.52                         | -1.01 | -0.99 | -0.19 |
| Limit                            |        |       | 0.75                    | 0.375   | 0.75   | 0.375  | 0.25                          | 0.25  | 45    | 22.5  |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):****e) Short-time current test for 600/5A CT:**

Test at rated short-time thermal current of 36kA rms for 1 sec and rated dynamic current of 90kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 50mm x 30mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 600/5A  |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 36kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 90kA peak   |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-05E/05 and B26-20-AA-05/06                          |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 93.87   | 36.68                         | 1.013                      | B26-20-AA013           |
| Date of test :10 <sup>th</sup> February 2020     |   |                               |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**e) Short-time current test for 600/5A CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 600/5A<br>Class 0.5<br>10VA |        |       | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |       |       |       |
|-------------------------------------|--------|-------|-------------------------|---------|---------|---------|-------------------------------|-------|-------|-------|
|                                     |        |       | at current (% of rated) |         |         |         | at current (% of rated)       |       |       |       |
|                                     |        |       | 5                       | 20      | 100     | 120     | 5                             | 20    | 100   | 120   |
| Before test                         | 25%VA  | 2.5VA | 0.1407                  | 0.1756  | 0.1982  | 0.2060  | 15.94                         | 13.21 | 8.36  | 7.76  |
|                                     | 100%VA | 10VA  | -0.4510                 | -0.3300 | -0.0968 | -0.0687 | 18.23                         | 13.35 | 2.98  | 2.30  |
| After test                          | 25%VA  | 2.5VA | 0.1387                  | 0.1685  | 0.1741  | 0.1795  | 17.85                         | 14.57 | 8.72  | 8.14  |
|                                     | 100%VA | 10VA  | -0.4510                 | -0.3290 | -0.1475 | -0.1340 | 19.10                         | 13.53 | 4.19  | 4.61  |
| Difference                          | 25%VA  | 2.5VA | 0.0020                  | 0.0071  | 0.0241  | 0.0265  | -1.91                         | -1.36 | -0.36 | -0.38 |
|                                     | 100%VA | 10VA  | 0.0000                  | -0.0010 | 0.0507  | 0.0653  | -0.87                         | -0.18 | -1.21 | -2.31 |
| Limit                               |        |       | 0.75                    | 0.375   | 0.25    | 0.25    | 45                            | 22.5  | 15    | 15    |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**f) Short-time current test for 1000/5A CT:**

Test at rated short-time thermal current of 60kA rms for 1 sec and rated dynamic current of 150kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 50mm x 30mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 1000/5A   |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 60kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 150kA peak  |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-06E/05 and B26-20-AA-06E/06                         |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 156.7   | 60.84                         | 1.012                      | B26-20-AA016           |
| Date of test : 10 <sup>th</sup> February 2020    |   |                               |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**f) Short-time current test for 1000/5A CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 1000/5A<br>Class 0.5<br>15VA |        |        | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |       |       |       |
|--------------------------------------|--------|--------|-------------------------|---------|---------|---------|-------------------------------|-------|-------|-------|
|                                      |        |        | at current (% of rated) |         |         |         | at current (% of rated)       |       |       |       |
|                                      |        |        | 5                       | 20      | 100     | 120     | 5                             | 20    | 100   | 120   |
| Before test                          | 25%VA  | 3.75VA | -0.0272                 | 0.0517  | 0.0864  | 0.0942  | 13.30                         | 9.33  | 5.07  | 4.79  |
|                                      | 100%VA | 15VA   | -0.0434                 | -0.2620 | -0.1064 | -0.0957 | 4.90                          | 7.61  | 2.23  | 2.21  |
| After test                           | 25%VA  | 3.75VA | -0.0629                 | 0.0163  | 0.0634  | 0.0683  | 14.77                         | 10.24 | 7.12  | 5.71  |
|                                      | 100%VA | 15VA   | -0.4950                 | -0.3220 | -0.2080 | -0.1506 | 12.83                         | 8.19  | 4.68  | 3.46  |
| Difference                           | 25%VA  | 3.75VA | 0.0357                  | 0.0354  | 0.0230  | 0.0259  | -1.47                         | -0.91 | -2.05 | -0.92 |
|                                      | 100%VA | 15VA   | 0.4516                  | 0.0600  | 0.1016  | 0.0549  | -7.93                         | -0.58 | -2.45 | -1.25 |
| Limit                                |        |        | 0.75                    | 0.375   | 0.25    | 0.25    | 45                            | 22.5  | 15    | 15    |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**g) Short-time current test for 1600/5A CT:**

Test at rated short-time thermal current of 96kA rms for 1 sec and rated dynamic current of 240kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 50mm x 30mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 1600/5A   |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 96kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 240kA peak  |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-07E/05 and B26-20-AA-07E/06                         |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 241.1   | 97.12                         | 1.012                      | B26-20-AA023           |
| Date of test : 10 <sup>th</sup> February 2020    |   |                               |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**g) Short-time current test for 1600/5A CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 1600/5A<br>Class 0.2S<br>15VA |        |        | Ratio error (±%)        |         |         |         |         | Phase displacement (±minutes) |       |       |      |      |
|---------------------------------------|--------|--------|-------------------------|---------|---------|---------|---------|-------------------------------|-------|-------|------|------|
|                                       |        |        | at current (% of rated) |         |         |         |         | at current (% of rated)       |       |       |      |      |
|                                       |        |        | 1                       | 5       | 20      | 100     | 120     | 1                             | 5     | 20    | 100  | 120  |
| Before test                           | 25%VA  | 3.75VA | -0.0896                 | 0.0016  | 0.0319  | 0.0165  | 0.0160  | 13.60                         | 9.51  | 6.82  | 5.47 | 5.85 |
|                                       | 100%VA | 15VA   | -0.3430                 | -0.1908 | -0.1201 | -0.0971 | -0.0843 | 13.19                         | 9.53  | 5.79  | 4.48 | 4.31 |
| After test                            | 25%VA  | 3.75VA | -0.1043                 | 0.0051  | 0.0296  | 0.0468  | 0.0636  | 13.60                         | 9.69  | 6.92  | 4.16 | 3.36 |
|                                       | 100%VA | 15VA   | -0.3550                 | -0.1917 | -0.1338 | -0.0505 | -0.0433 | 13.24                         | 9.60  | 5.88  | 2.91 | 2.72 |
| Difference                            | 25%VA  | 3.75VA | 0.0147                  | -0.0035 | 0.0023  | -0.0303 | -0.0476 | 00.00                         | -0.18 | -0.1  | 1.31 | 2.49 |
|                                       | 100%VA | 15VA   | 0.0120                  | 0.0009  | 0.0137  | -0.0466 | -0.0410 | -0.05                         | -0.07 | -0.09 | 1.57 | 1.59 |
| Limit                                 |        |        | 0.375                   | 0.175   | 0.1     | 0.1     | 0.1     | 15                            | 8     | 5     | 5    | 5    |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**h) Short-time current test for 2500/5A CT:**

Test at rated short-time thermal current of 150kA rms for 1 sec and rated dynamic current of 375kA peak.

| <b>Condition before test:</b>                    | New sample   |                               |                            |                        |
|--|--|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 2 x 80mm x 10mm copper bars |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                    |                               |                            |                        |
| <b>Ratio:</b>                                    | 2500/5A  |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 150kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 375kA peak   |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-08E/05 and B26-20-AA-08E/06                          |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>   |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                                | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 386.7  | 153.4                         | 1.014                      | B26-20-AA027           |
| Date of test :11 <sup>th</sup> February 2020     |  |                               |                            |                        |



**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**h) Short-time current test for 2500/5A CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 2500/5A<br>Class 0.2S<br>15VA |        |        | Ratio error (±%)        |         |        |        |         | Phase displacement (±minutes) |       |       |        |        |
|---------------------------------------|--------|--------|-------------------------|---------|--------|--------|---------|-------------------------------|-------|-------|--------|--------|
|                                       |        |        | at current (% of rated) |         |        |        |         | at current (% of rated)       |       |       |        |        |
|                                       |        |        | 1                       | 5       | 20     | 100    | 120     | 1                             | 5     | 20    | 100    | 120    |
| Before test                           | 25%VA  | 3.75VA | -0.0044                 | 0.0765  | 0.0903 | 0.0951 | 0.1066  | 7.87                          | 3.50  | 2.60  | 2.13   | 1.968  |
|                                       | 100%VA | 15VA   | -0.0833                 | 0.0228  | 0.0474 | 0.0623 | 0.0639  | 6.58                          | 3.68  | 2.73  | 1.938  | 1.776  |
| After test                            | 25%VA  | 3.75VA | -0.0698                 | 0.0621  | 0.0824 | 0.0881 | 0.1498  | 8.70                          | 4.26  | 3.22  | 2.39   | 2.12   |
|                                       | 100%VA | 15VA   | -0.1874                 | -0.0040 | 0.0273 | 0.0465 | 0.0906  | 9.12                          | 4.81  | 3.57  | 2.09   | 1.766  |
| Difference                            | 25%VA  | 3.75VA | 0.0654                  | 0.0144  | 0.0079 | 0.0070 | -0.0432 | -0.83                         | -0.76 | -0.62 | -0.26  | -0.152 |
|                                       | 100%VA | 15VA   | 0.1041                  | 0.0268  | 0.0201 | 0.0158 | -0.0267 | -2.54                         | -1.13 | -0.84 | -0.152 | 0.01   |
| Limit                                 |        |        | 0.375                   | 0.175   | 0.1    | 0.1    | 0.1     | 15                            | 8     | 5     | 5      | 5      |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**i) Short-time current test for 3000/5A, 15VA, Class 0.2S CT:**

Test at rated short-time thermal current of 60kA rms for 1 sec and rated dynamic current of 150kA peak.

| <b>Condition before test:</b>                    | New sample  |                           |                            |                        |
|--|---|---------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 50mm x 30mm copper bar |                           |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                           |                            |                        |
| <b>Ratio:</b>                                    | 3000/5A, 15VA, Class 0.2S                                     |                           |                            |                        |
| <b>Rated short-time thermal current:</b>         | 60kA rms  |                           |                            |                        |
| <b>Rated dynamic current:</b>                    | 150kA peak  |                           |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-09E/05 and B26-20-AA-09E/06                         |                           |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                           | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical kA peak</b>                                   | <b>Symmetrical kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 155.7   | 60.44                     | 1.012                      | B26-20-AA019           |
| Date of test : 10 <sup>th</sup> February 2020    |   |                           |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**i) Short-time current test for 3000/5A, 15VA, Class 0.2S (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 3000/5A<br>Class 0.2S<br>15VA |        |        | Ratio error ( $\pm\%$ ) |         |         |         |         | Phase displacement ( $\pm$ minutes) |      |      |       |       |
|---------------------------------------|--------|--------|-------------------------|---------|---------|---------|---------|-------------------------------------|------|------|-------|-------|
|                                       |        |        | at current (% of rated) |         |         |         |         | at current (% of rated)             |      |      |       |       |
|                                       |        |        | 1                       | 5       | 20      | 100     | 120     | 1                                   | 5    | 20   | 100   | 120   |
| Before test                           | 25%VA  | 3.75VA | -0.0716                 | -0.0059 | 0.0105  | 0.0173  | 0.0182  | 4.98                                | 2.58 | 1.88 | 1.422 | 1.348 |
|                                       | 100%VA | 15VA   | -0.1387                 | -0.0441 | -0.0213 | -0.0068 | -0.0043 | 5.18                                | 2.78 | 2.03 | 1.245 | 1.126 |
| After test                            | 25%VA  | 3.75VA | -0.0950                 | -0.0070 | 0.0119  | 0.0204  | 0.0214  | 4.89                                | 2.42 | 1.72 | 1.28  | 1.21  |
|                                       | 100%VA | 15VA   | -0.1482                 | -0.0455 | -0.0170 | -0.0020 | 0.0010  | 4.86                                | 2.49 | 1.78 | 1.132 | 1.101 |
| Difference                            | 25%VA  | 3.75VA | 0.0234                  | 0.0011  | -0.0014 | -0.0031 | -0.0032 | 0.09                                | 0.16 | 0.16 | 0.142 | 0.138 |
|                                       | 100%VA | 15VA   | 0.0095                  | 0.0014  | -0.0043 | -0.0048 | -0.0053 | 0.32                                | 0.29 | 0.25 | 0.113 | 0.025 |
| Limit                                 |        |        | 0.375                   | 0.175   | 0.1     | 0.1     | 0.1     | 15                                  | 8    | 5    | 5     | 5     |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):****j) Short-time current test for 3000/5A, 45VA, Class 1 split core CT:**

Test at rated short-time thermal current of 60kA rms for 1 sec and rated dynamic current of 150kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 50mm x 30mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 3000/5A, 45VA, Class 1  |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 60kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 150kA peak  |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-10E/05 and B26-20-AA-10E/06                         |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 154.8   | 60.12                         | 1.012                      | B26-20-AA018           |
| Date of test : 10 <sup>th</sup> February 2020    |   |                               |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**j) Short-time current test for 3000/5A, 45VA, Class 1 split core CT (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Clause No. 7.3.5.201)**

| Rating: 3000/5A<br>Class 1<br>45VA |        |         | Ratio error (±%)        |         |         |         | Phase displacement (±minutes) |       |       |       |
|------------------------------------|--------|---------|-------------------------|---------|---------|---------|-------------------------------|-------|-------|-------|
|                                    |        |         | at current (% of rated) |         |         |         | at current (% of rated)       |       |       |       |
|                                    |        |         | 5                       | 20      | 100     | 120     | 5                             | 20    | 100   | 120   |
| Before test                        | 25%VA  | 11.25VA | -0.0189                 | 0.0420  | 0.0745  | 0.0935  | 8.09                          | 7.68  | 7.11  | 5.16  |
|                                    | 100%VA | 45VA    | -0.2410                 | -0.1598 | -0.0960 | -0.3110 | 14.94                         | 14.24 | 10.59 | 12.79 |
| After test                         | 25%VA  | 11.25VA | 0.0948                  | 0.1885  | 0.2560  | 0.1928  | 7.46                          | 6.32  | 4.53  | 4.99  |
|                                    | 100%VA | 45VA    | -0.1070                 | 0.0150  | 0.0300  | -0.2000 | 13.51                         | 11.59 | 9.78  | 12.00 |
| Difference                         | 25%VA  | 11.25VA | -0.1137                 | -0.1465 | -0.1815 | -0.0993 | 0.63                          | 1.36  | 2.58  | 0.17  |
|                                    | 100%VA | 45VA    | -0.1340                 | -0.1748 | -0.1260 | -0.1110 | 1.43                          | 2.65  | 0.81  | 0.79  |
| Limit                              |        |         | 1.5                     | 0.75    | 0.5     | 0.5     | 90                            | 45    | 30    | 30    |

**Result:**

The difference in current error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**k) Short-time current test for 3000/5A, 15VA, Class 0.2S (ring type) CT:**

Test at rated short-time thermal current of 60kA rms for 1 sec and rated dynamic current of 150kA peak.

| <b>Condition before test:</b>                    | New sample  |                               |                            |                        |
|--|---|-------------------------------|----------------------------|------------------------|
| <b>Test connection details:</b>                  | Primary conductor cross section of 1 x 50mm x 30mm copper bar |                               |                            |                        |
| <b>Short-circuit position:</b>                   | Secondary winding terminals                                   |                               |                            |                        |
| <b>Ratio:</b>                                    | 3000/5A, 15VA, Class 0.2S (ring type)                         |                               |                            |                        |
| <b>Rated short-time thermal current:</b>         | 60kA rms  |                               |                            |                        |
| <b>Rated dynamic current:</b>                    | 150kA peak  |                               |                            |                        |
| <b>Photograph Nos</b>                            | B26-20-AA-11E/05 and B26-20-AA-11E/06                         |                               |                            |                        |
| <b>Test</b>                                      | <b>Current</b>  |                               | <b>Duration in Seconds</b> | <b>Oscillogram no.</b> |
|  | <b>Asymmetrical<br/>kA peak</b>                               | <b>Symmetrical<br/>kA rms</b> |                            |                        |
| Rated short-time and peak withstand current test | 155.7   | 60.60                         | 1.012                      | B26-20-AA020           |
| Date of test :10 <sup>th</sup> February 2020     |   |                               |                            |                        |

**8. Short-time Current Tests (Clause 7.2.201) (continued):**

**k) Short-time current test for 3000/5A, 15VA, Class 0.2S (ring type) (contd.)**

**Test Results After Short-time Current Test**

After the short-time current tests, the current transformer was cooled to ambient air temperature and the following requirements as per Clause 7.2.201 were verified as detailed below:

**1) No Visible External Damage Observed. (Clause No. 7.1.a)**

**2) Tests for ratio error and phase displacement (Accuracy Test) (Cl. No. 7.3.5.201)**

| Rating: 3000/5A<br>Class 0.2S<br>15VA<br>(Ring type) |        |        | Ratio error (±%)        |         |         |         |         | Phase displacement (±minutes) |       |       |        |        |
|--|--------|--------|-------------------------|---------|---------|---------|---------|-------------------------------|-------|-------|--------|--------|
|  |        |        | at current (% of rated) |         |         |         |         | at current (% of rated)       |       |       |        |        |
|  |        |        | 1                       | 5       | 20      | 100     | 120     | 1                             | 5     | 20    | 100    | 120    |
| Before test  | 25%VA  | 3.75VA | 0.0387                  | 0.0630  | 0.0685  | 0.0673  | 0.0658  | 4.51                          | 2.65  | 2.09  | 1.590  | 1.501  |
|  | 100%VA | 15VA   | -0.0244                 | 0.0242  | 0.0369  | 0.0423  | 0.0400  | 4.91                          | 2.91  | 2.24  | 1.489  | 1.375  |
| After test   | 25%VA  | 3.75VA | 0.0305                  | 0.0636  | 0.0710  | 0.0695  | 0.0655  | 6.12                          | 4.20  | 2.41  | 1.75   | 1.70   |
|  | 100%VA | 15VA   | -0.0622                 | 0.0246  | 0.0404  | 0.0477  | 0.0449  | 5.84                          | 3.13  | 2.42  | 1.57   | 1.46   |
| Difference   | 25%VA  | 3.75VA | 0.0082                  | -0.0006 | -0.0025 | -0.0022 | 0.0003  | -1.61                         | -1.55 | -0.32 | -0.16  | -0.199 |
|  | 100%VA | 15VA   | 0.0378                  | -0.0004 | -0.0035 | -0.0054 | -0.0049 | -0.93                         | -0.22 | -0.18 | -0.081 | -0.085 |
| Limit  |        |        | 0.375                   | 0.175   | 0.1     | 0.1     | 0.1     | 15                            | 8     | 5     | 5      | 5      |

**Result:**

The difference in the ratio error and phase displacement measured before and after short-time current test was within half the limit of accuracy class as specified in standard.

**3) Power-frequency withstand tests (at 90% test voltage)**

Primary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the primary winding and earth.

Secondary winding:

The current transformer withstood 3600V rms (f = 50Hz) applied for 60 seconds between the terminals of the secondary windings (connected together) and earth.

**4) Physical Examination (Clause No. 7.1.d)**

The insulation next to the surface of the conductor did not show significant deterioration (such as carbonization) upon undergoing physical examination.

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E




Diagram No.-B26-20-AA/D1  
Test set up for short-time current test




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020

Osc. no: B26-20-AA 004

|              |              |
|--------------|--------------|
| $V_r$        | 5,026 V      |
| $I_r$ (rms)  | 6,059 kA     |
| $I_r$ (peak) | 15,80 kA     |
| $t_r$        | 1,012 s      |
| $I_r^2 t$    | 3,96E+07 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 006

|              |             |
|--------------|-------------|
| $V_r$        | 9,902 V     |
| $I_r$ (rms)  | 12,23 kA    |
| $I_r$ (peak) | 31,36 kA    |
| $t_r$        | 1,003 s     |
| $I_r^2 t$    | 1,6E+08 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 008

|              |              |
|--------------|--------------|
| $V_r$        | 14,75 V      |
| $I_r$ (rms)  | 18,41 kA     |
| $I_r$ (peak) | 46,81 kA     |
| $t_r$        | 1,002 s      |
| $I_r^2 t$    | 3,55E+08 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 010

|              |              |
|--------------|--------------|
| $V_r$        | 19,29 V      |
| $I_r$ (rms)  | 24,24 kA     |
| $I_r$ (peak) | 61,78 kA     |
| $t_r$        | 1,012 s      |
| $I_r^2 t$    | 6,22E+08 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 013

|              |              |
|--------------|--------------|
| $V_r$        | 28,70 V      |
| $I_r$ (rms)  | 36,68 kA     |
| $I_r$ (peak) | 93,87 kA     |
| $t_r$        | 1,013 s      |
| $I_r^2 t$    | 1,43E+09 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 016

|              |              |
|--------------|--------------|
| $V_r$        | 47,27 V      |
| $I_r$ (rms)  | 60,84 kA     |
| $I_r$ (peak) | 156,7 kA     |
| $t_r$        | 1,012 s      |
| $I_r^2 t$    | 3,95E+09 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 018

|              |              |
|--------------|--------------|
| $V_r$        | 45,92 V      |
| $I_r$ (rms)  | 60,12 kA     |
| $I_r$ (peak) | 154,8 kA     |
| $t_r$        | 1,012 s      |
| $I_r^2 t$    | 3,86E+09 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 019

|              |              |
|--------------|--------------|
| $V_r$        | 46,63 V      |
| $I_r$ (rms)  | 60,44 kA     |
| $I_r$ (peak) | 155,7 kA     |
| $t_r$        | 1,012 s      |
| $I_r^2 t$    | 3,91E+09 AAs |






## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 020

|              |              |
|--------------|--------------|
| $V_r$        | 46,65 V      |
| $I_r$ (rms)  | 60,60 kA     |
| $I_r$ (peak) | 155,7 kA     |
| $t_r$        | 1,012 s      |
| $I_r^2 t$    | 3,92E+09 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 10/02/2020  
Osc. no: B26-20-AA 023

|              |              |
|--------------|--------------|
| $V_r$        | 74,52 V      |
| $I_r$ (rms)  | 97,12 kA     |
| $I_r$ (peak) | 241,1 kA     |
| $t_r$        | 1,012 s      |
| $I_r^2 t$    | 9,84E+09 AAs |




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

Date: 11/02/2020  
Osc. no: B26-20-AA 027


|              |             |
|--------------|-------------|
| $V_r$        | 51,64 V     |
| $I_r$ (rms)  | 153,4 kA    |
| $I_r$ (peak) | 386,7 kA    |
| $t_r$        | 1,014 s     |
| $I_r^2 t$    | 2,5E+10 AAs |



## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E


a) 100/5A, 5VA, Class 0.5



a) 100/5A CT

Photograph no. B26-20-AA-01E/01

Power-frequency voltage withstand tests on primary and secondary terminals



a) 100/5A CT


Photograph no. B26-20-AA-01E/02

Tests for accuracy




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



a) 100/5A CT  
Photograph no. B26-20-AA-01E/05  
Short-time current tests




a) 100/5A CT  
Photograph no. B26-20-AA-01E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

b) 200/5A, 10VA, Class 0.5



b) 200/5A CT

Photograph no. B26-20-AA-02E/01

Power-frequency voltage withstand tests on primary and secondary terminals



b) 200/5A CT

Photograph no. B26-20-AA-02E/02

Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



b) 200/5A CT  
Photograph no. B26-20-AA-02E/03  
Inter-turn overvoltage test



b) 200/5A CT  
Photograph no. B26-20-AA-02E/04  
Temperature-rise test



## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



b) 200/5A CT  
Photograph no. B26-20-AA-02E/05  
Short-time current tests




b) 200/5A CT  
Photograph no. B26-20-AA-02E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E


c) 300/5A, 10VA, Class 0.5



c) 300/5A CT

Photograph no. B26-20-AA-03E/01

Power-frequency voltage withstand tests on primary and secondary terminals




c) 300/5A CT

Photograph no. B26-20-AA-03E/02

Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



c) 300/5A CT  
Photograph no. B26-20-AA-03E/03  
Inter-turn overvoltage test



c) 300/5A CT  
Photograph no. B26-20-AA-03E/04  
Temperature-rise test

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



c) 300/5A CT  
Photograph no. B26-20-AA-03E/05  
Short-time current tests




c) 300/5A CT  
Photograph no. B26-20-AA-03E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E


d) 400/5A, 5VA, Class 1



d) 400/5A CT

Photograph no. B26-20-AA-04E/01

Power-frequency voltage withstand tests on primary and secondary terminals



d) 400/5A CT

Photograph no. B26-20-AA-04E/02

Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



d) 400/5A CT  
Photograph no. B26-20-AA-04E/03  
Inter-turn overvoltage test



d) 400/5A CT  
Photograph no. B26-20-AA-04E/04  
Temperature-rise test

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



d) 400/5A CT  
Photograph no. B26-20-AA-04E/05  
Short-time current tests




d) 400/5A CT  
Photograph no. B26-20-AA-04E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

e) 600/5A, 10VA, Class 0.5



e) 600/5A CT

Photograph no. B26-20-AA-05E/01

Power-frequency voltage withstand tests on primary and secondary terminals



e) 600/5A CT


Photograph no. B26-20-AA-05E/02

Tests for accuracy



## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



e) 600/5A CT  
Photograph no. B26-20-AA-05E/03  
Inter-turn overvoltage test



e) 600/5A CT  
Photograph no. B26-20-AA-05E/04  
Temperature-rise test

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



e) 600/5A CT  
Photograph no. B26-20-AA-05E/05  
Short-time current tests




e) 600/5A CT  
Photograph no. B26-20-AA-05E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

f) 1000/5A, 15VA, Class 0.5



f) 1000/5A CT

Photograph no. B26-20-AA-06E/01

Power-frequency voltage withstand tests on primary and secondary terminals




f) 1000/5A CT

Photograph no. B26-20-AA-06E/02

Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



f) 1000/5A CT  
Photograph no. B26-20-AA-06E/03  
Inter-turn overvoltage test



f) 1000/5A CT  
Photograph no. B26-20-AA-06E/04  
Temperature-rise test

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



f) 1000/5A CT  
Photograph no. B26-20-AA-06E/05  
Short-time current tests



f) 1000/5A CT  
Photograph no. B26-20-AA-06E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E


g) 1600/5A, 15VA, Class 0.2S



g) 1600/5A CT

Photograph no. B26-20-AA-07E/01

Power-frequency voltage withstand tests on primary and secondary terminals



g) 1600/5A CT

Photograph no. B26-20-AA-07E/02

Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



g) 1600/5A CT  
Photograph no. B26-20-AA-07E/03  
Inter-turn overvoltage test



g) 1600/5A CT  
Photograph no. B26-20-AA-07/04  
Temperature-rise test


**RECORD OF PROVING TESTS**

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

**ASTA**



g) 1600/5A CT  
Photograph no. B26-20-AA-07E/05  
Short-time current tests




g) 1600/5A CT  
Photograph no. B26-20-AA-07E/06  
After short-time current tests



## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

h) 2500/5A, 15VA, Class 0.2S



h) 2500/5A CT

Photograph no. B26-20-AA-08E/01

Power-frequency voltage withstand tests on primary and secondary terminals



h) 2500/5A CT

Photograph no. B26-20-AA-08E/02

Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E




h) 2500/5A CT  
Photograph no. B26-20-AA-08E/03  
Inter-turn overvoltage test




h) 2500/5A CT  
Photograph no. B26-20-AA-08/04  
Temperature-rise test

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



h) 2500/5A CT  
Photograph no. B26-20-AA-08E/05  
Short-time current tests




h) 2500/5A CT  
Photograph no. B26-20-AA-08E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

i) 3000/5A, 15VA, Class 0.2S



i) 3000/5A CT

Photograph no. B26-20-AA-09E/01

Power-frequency voltage withstand tests on primary and secondary terminals



i) 3000/5A CT

Photograph no. B26-20-AA-09E/02

Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



i) 3000/5A CT  
Photograph no. B26-20-AA-09E/03  
Inter-turn overvoltage test



i) 3000/5A CT  
Photograph no. B26-20-AA-09E/04  
Temperature-rise test

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



i) 3000/5A CT  
Photograph no. B26-20-AA-09E/05  
Short-time current tests




i) 3000/5A CT  
Photograph no. B26-20-AA-09E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

j) 3000/5A, 45VA, Class 1



j) 3000/5A CT

Photograph no. B26-20-AA-10E/01

Power-frequency voltage withstand tests on primary and secondary terminals




j) 3000/5A CT

Photograph no. B26-20-AA-10E/02

Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



j) 3000/5A CT  
Photograph no. B26-20-AA-10E/03  
Inter-turn overvoltage test



j) 3000/5A CT  
Photograph no. B26-20-AA-10E/04  
Temperature-rise test




## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



j) 3000/5A CT

Photograph no. B26-20-AA-10E/05  
Short-time current tests




j) 3000/5A CT

Photograph no. B26-20-AA-10E/06  
After short-time current tests

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E

k) 3000/5A, 15VA, Class 0.2S (ring type)



k) 3000/5A CT

Photograph no. B26-20-AA-11E/01

Power-frequency voltage withstand tests on primary and secondary terminals



k) 3000/5A CT

Photograph no. B26-20-AA-11E/02


Tests for accuracy

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



k) 3000/5A CT  
Photograph no. B26-20-AA-11E/03  
Inter-turn overvoltage test



k) 3000/5A CT  
Photograph no. B26-20-AA-11E/04  
Temperature-rise test

## RECORD OF PROVING TESTS

Laboratory Ref. No: B26-20-AA-01E/02E/03E/04E/05E/06E/07E/08E/09E/10E/11E



k) 3000/5A CT

Photograph no. B26-20-AA-11E/05


Short-time current tests



k) 3000/5A CT


Photograph no. B26-20-AA-11E/06

After short-time current tests




PLAN


|          |                       |
|----------|-----------------------|
| VERITEK  | FS5 50 - 60 Hz E      |
| 100 / 5  | 0.72 / 4KV            |
| VA - 5   | Ith = 60In            |
| CL - 0.5 | Sr.No.: 1219/01/26574 |



SECTIONAL VIEW



ELEVATION



SIDE VIEW

|           |                          |
|-----------|--------------------------|
| SECONDARY | 20 TURNS                 |
| WIRE      | 19 X 1 SWG<br>25 X 1 SWG |
| MATERIAL  | DUAL COAT COPPER WIRE    |



**VERITEK ENGINEERING PVT. LTD.**


Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com

|       |       |            |                             |
|-------|-------|------------|-----------------------------|
| DRN.  | R. A. | 07.12.2019 | TITLE : Current Transformer |
| SCALE | NTS   |            | MODEL NO : VIPS 50102630    |

DRG. NO.: VEPL / RA / VIPS 5010 - 100 / 5


R - 0






PLAN


|          |                        |
|----------|------------------------|
| VERITEK  | FS5 50 - 60 Hz E       |
| 200 / 5  | 0.72 / 4KV             |
| VA - 10  | Ith = 60In             |
| CL - 0.5 | Sr.No. : 1219/01/26575 |



SECTIONAL VIEW



ELEVATION



SIDE VIEW

|           |                       |
|-----------|-----------------------|
| SECONDARY | 40 TURNS              |
| WIRE      | 25 X 5 SWG            |
| MATERIAL  | DUAL COAT COPPER WIRE |



**VERITEK ENGINEERING PVT. LTD.**


Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com

|       |       |            |                             |
|-------|-------|------------|-----------------------------|
| DRN.  | R. A. | 07.12.2019 | TITLE : Current Transformer |
| SCALE | NTS   |            | MODEL NO : VIPS 50102630    |

DRG. NO. : VEPL / RA / VIPS 5010 - 200 / 5


R - 0






PLAN


|          |                        |
|----------|------------------------|
| VERITEK  | FS5 50 - 60 Hz E       |
| 300 / 5  | 0.72 / 4KV             |
| VA - 10  | Ith = 60In             |
| CL - 0.5 | Sr.No. : 1219/01/26576 |



SECTIONAL VIEW



ELEVATION



SIDE VIEW

|           |                       |
|-----------|-----------------------|
| SECONDARY | 60 TURNS              |
| WIRE      | 23 X 4 SWG            |
| MATERIAL  | DUAL COAT COPPER WIRE |



**VERITEK ENGINEERING PVT. LTD.**

Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com




|       |       |            |            |                     |
|-------|-------|------------|------------|---------------------|
| DRN.  | R. A. | 07.12.2019 | TITLE :    | Current Transformer |
| SCALE | NTS   |            | MODEL NO : | VIPS 40103240       |


DRG. NO. : VEPL / RA / VIPS 4010 - 300 / 5

R - 0


|          |                       |
|----------|-----------------------|
| VERITEK  | FS5 50 - 60 Hz E      |
| 400 / 5  | 0.72 / 4KV            |
| VA - 5   | Ith = 60In            |
| CL - 1.0 | Sr.No.: 1219/01/26572 |




PLAN



ELEVATION



SIDE VIEW



SECTIONAL VIEW

|           |                       |
|-----------|-----------------------|
| SECONDARY | 80 TURNS              |
| WIRE      | 23 X 2 SWG            |
| MATERIAL  | DUAL COAT COPPER WIRE |



**VERITEK ENGINEERING PVT. LTD.**

Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com


|       |       |            |            |                     |
|-------|-------|------------|------------|---------------------|
| DRN.  | R. A. | 07.12.2019 | TITLE :    | Current Transformer |
| SCALE | NTS   |            | MODEL NO : | VIPS 30103010       |

DRG. NO.: VEPL / RA / VIPS 3010 - 400/5


R - 0








PLAN




ELEVATION



|          |                        |
|----------|------------------------|
| VERITEK  | FS5 50 - 60 Hz E       |
| 600 / 5  | 0.72 / 4KV             |
| VA - 10  | Ith = 60In             |
| CL - 0.5 | Sr.No. : 1219/01/26579 |



SECTIONAL VIEW



SIDE VIEW

|                |                       |
|----------------|-----------------------|
| SECONDARY WIRE | 120 TURNS             |
|                | 21 X 2 SWG            |
| MATERIAL       | DUAL COAT COPPER WIRE |




**VERITEK ENGINEERING PVT. LTD.**

Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com

|       |       |            |                             |
|-------|-------|------------|-----------------------------|
| DRN.  | R. A. | 07.12.2019 | TITLE : Current Transformer |
| SCALE | NTS   |            | MODEL NO : VIPS 63104460    |


DRG. NO. : VEPL / RA / VIPS 6310 - 600 / 5

R - 0




PLAN

|          |                       |
|----------|-----------------------|
| VERITEK  | FS5 50 - 60 Hz E      |
| 1000 / 5 | 0.72 / 4KV            |
| VA - 15  | Ith = 60In            |
| CL - 0.5 | Sr.No.: 1219/01/26580 |




SECTIONAL VIEW

|           |                       |
|-----------|-----------------------|
| SECONDARY | 200 TURNS             |
| WIRE      | 21 X 2 SWG            |
| MATERIAL  | DUAL COAT COPPER WIRE |



SIDE VIEW



ELEVATION



**VERITEK ENGINEERING PVT. LTD.**

Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com

DRN.

R. A.

07.12.2019

TITLE : Current Transformer

SCALE

NTS

MODEL NO : VIPS 63104460


DRG. NO.:

VEPL / RA / VIPS 6310 - 1000 / 5


R - 0




|           |                        |
|-----------|------------------------|
| VERITEK   | FS5 50 - 60 HzE        |
| 1600 / 5  | 0.72 / 4KV             |
| VA - 15   | Ith = 60In             |
| CL - 0.2S | Sr.No. : 1219/01/26581 |




PLAN



ELEVATION



SECTIONAL VIEW



SIDE VIEW

|           |                       |
|-----------|-----------------------|
| SECONDARY | 320 TURNS             |
| WIRE      | 19 X 1 SWG            |
| MATERIAL  | 21 X 1 SWG            |
|           | DUAL COAT COPPER WIRE |



**VERITEK ENGINEERING PVT. LTD.**


Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com

|       |       |            |            |                     |
|-------|-------|------------|------------|---------------------|
| DRN.  | R. A. | 07.12.2019 | TITLE :    | Current Transformer |
| SCALE | NTS   |            | MODEL NO : | VIPS 80105580       |

DRG. NO. : VEPL / RA / VIPS 8010 - 1600 / 5


R - 0






PLAN


|           |                        |
|-----------|------------------------|
| VERITEK   | FS5 50 - 60 Hz E       |
| 2500 / 5  | 0.72 / 4KV             |
| VA - 15   | Ith = 60In             |
| CL - 0.2S | Sr.No. : 1219/01/26584 |



SECTIONAL VIEW



SIDE VIEW



ELEVATION

|           |                       |
|-----------|-----------------------|
| SECONDARY | 500 TURNS             |
| WIRE      | 19 X 1 SWG            |
|           | 21 X 1 SWG            |
| MATERIAL  | DUAL COAT COPPER WIRE |



**VERITEK ENGINEERING PVT. LTD.**

Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com

DRN.

R. A.

07.12.2019

TITLE : Current Transformer

SCALE

NTS


MODEL NO : VIPS 100308510

DRG. NO.:

VEPL / RA / VIPS 10030 - 2500 / 5


R - 0






PLAN


|           |                        |
|-----------|------------------------|
| VERITEK   | FS5 50 - 60 Hz E       |
| 3000 / 5  | 0.72 / 4KV             |
| VA - 15   | Ith = 60In             |
| CL - 0.2S | Sr.No. : 1219/01/26585 |



SECTIONAL VIEW



SIDE VIEW



ELEVATION

|           |                       |
|-----------|-----------------------|
| SECONDARY | 600 TURNS             |
| WIRE      | 19 X 1 SWG            |
|           | 21 X 1 SWG            |
| MATERIAL  | DUAL COAT COPPER WIRE |



**VERITEK ENGINEERING PVT. LTD.**

Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com

DRN.

R. A.

07.12.2019

TITLE : Current Transformer

SCALE

NTS


MODEL NO : VIPS 100308510

DRG. NO.:

VEPL / RA / VIPS 10030 - 3000 / 5


R - 0






PLAN


|          |                        |
|----------|------------------------|
| VERITEK  | Fs10 50 - 60 Hz H      |
| 3000 / 5 | 0.72 / 4KV             |
| VA - 45  | lth = 60In             |
| CL - 1   | Sr.No. : 1219/01/20587 |



SECTIONAL VIEW



SIDE VIEW



ELEVATION

|           |                       |
|-----------|-----------------------|
| SECONDARY | 600 TURNS             |
| WIRE      | 19 X 1 SWG            |
| MATERIAL  | 21 X 1 SWG            |
|           | DUAL COAT COPPER WIRE |



**VERITEK ENGINEERING PVT. LTD.**

Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com


|       |       |            |            |               |
|-------|-------|------------|------------|---------------|
| DRN.  | R. A. | 20.03.2020 | TITLE :    | SPLIT CORE CT |
| SCALE | NTS   |            | MODEL NO : | VIPS SC01     |

DRG. NO. : VEPL / RA / VIPS SC01


R - 0




|           |                       |
|-----------|-----------------------|
| VERITEK   | Fs5 50 - 60 Hz H      |
| 3000 / 5  | 0.72 / 4KV            |
| VA - 15   | Ith = 60In            |
| CL - 0.25 | Sr.No.: 0120/01/15148 |




PLAN



SECTIONAL VIEW



SIDE VIEW



ELEVATION

|           |                          |
|-----------|--------------------------|
| SECONDARY | 600 TURNS                |
| WIRE      | 19 X 1 SWG<br>21 X 1 SWG |
| MATERIAL  | DUAL COAT COPPER WIRE    |



**VERITEK**

**VERITEK ENGINEERING PVT. LTD.**

Plot No. 222, EL-Electronic Zone,  
MIDC, TTC Industrial Area,  
Mahape, Navi Mumbai - 400701, India  
Tel. : +91-74 0041 5391 / 92 / 93  
Email : sales@veritekindia.com  
Web : www.veritekindia.com

|       |       |            |            |               |
|-------|-------|------------|------------|---------------|
| DRN.  | R. A. | 20.03.2020 | TITLE :    | RMCT BIG      |
| SCALE | NTS   |            | MODEL NO : | VIPS 11315940 |

DRG. NO. : VEPL / RA / VIPS 11315940

R - 0

